

**EMSL Analytical, Inc.**

200 Route 130 North, Cinnaminson, NJ 08077

Phone/Fax: (800) 220-3675 / (856) 786-0327

<http://www.EMSL.com>cinnaminsonradonlab@emsl.com

EMSL Order: 381603378

CustomerID: PGCS62

CustomerPO:

ProjectID:

Attn: **Karen Bowlding**
Prince George's County School
13300 Old Marlboro Pike
Upper Marlboro, MD 20772

Phone: (301) 952-6559
 Fax: (301) 952-0346
 Received: 04/08/16 10:33 AM
 Analysis Date: 4/9/2016
 Collected: 4/1/2016

Project: **Dora Kennedy (Old Greenbelt MS)**

Test Site: **Dora Kennedy (Old Greenbelt MS)**
Greenbelt, MD 20770

Test Report: Radon in Air Test Results**Samples for EMSL Kit 142140**

Liquid Scintillation ID	Location	Radon Activity pCi/L	Start	Stop	Temperature F	Humidity %	Sample Type
239679	20	0.2	4/1/2016	4/4/2016	70	50	Customer
381603378-0001			9:25:00 AM	6:35:00 AM			

Sample Notes:**Samples for EMSL Kit 142135**

Liquid Scintillation ID	Location	Radon Activity pCi/L	Start	Stop	Temperature F	Humidity %	Sample Type
239671	23	0.1	4/1/2016	4/4/2016	70	50	Customer
381603378-0002			9:26:00 AM	6:36:00 AM			

Sample Notes:

238019	23	-0.1	4/1/2016	4/4/2016	70	50	Blank
381603378-0003			9:26:00 AM	6:36:00 AM			

Sample Notes:**Samples for EMSL Kit 142137**

Liquid Scintillation ID	Location	Radon Activity pCi/L	Start	Stop	Temperature F	Humidity %	Sample Type
239660	Resource Room	0.1	4/1/2016	4/4/2016	70	50	Customer
381603378-0004			9:27:00 AM	6:37:00 AM			

Sample Notes:**Samples for EMSL Kit 142136**

Liquid Scintillation ID	Location	Radon Activity pCi/L	Start	Stop	Temperature F	Humidity %	Sample Type
239748	ESOL	0.2	4/1/2016	4/4/2016	70	50	Customer
381603378-0005			9:28:00 AM	6:38:00 AM			

Sample Notes:

**EMSL Analytical, Inc.**

200 Route 130 North, Cinnaminson, NJ 08077
 Phone/Fax: (800) 220-3675 / (856) 786-0327
<http://www.EMSL.com> cinnaminsonradonlab@emsl.com

EMSL Order: 381603378
 CustomerID: PGCS62
 CustomerPO:
 ProjectID:

Attn: **Karen Bowlding**
Prince George's County School
13300 Old Marlboro Pike
Upper Marlboro, MD 20772

Phone: (301) 952-6559
 Fax: (301) 952-0346
 Received: 04/08/16 10:33 AM
 Analysis Date: 4/9/2016
 Collected: 4/1/2016

Project: **Dora Kennedy (Old Greenbelt MS)**

Test Site: **Dora Kennedy (Old Greenbelt MS)**
Greenbelt, MD 20770

Test Report: Radon in Air Test Results**Samples for EMSL Kit 142138**

Liquid Scintillation ID	Location	Radon Activity pCi/L	Start	Stop	Temperature F	Humidity %	Sample Type
239676	26	0	4/1/2016	4/4/2016	70	50	Customer
381603378-0006			9:29:00 AM	6:39:00 AM			

Sample Notes:

238215	26	0.1	4/1/2016	4/4/2016	70	50	Duplicate
381603378-0007			9:29:00 AM	6:39:00 AM			

Sample Notes:**Duplicate RPD = 200%****Samples for EMSL Kit 142139**

Liquid Scintillation ID	Location	Radon Activity pCi/L	Start	Stop	Temperature F	Humidity %	Sample Type
239742	29	0.1	4/1/2016	4/4/2016	70	50	Customer
381603378-0008			9:30:00 AM	6:40:00 AM			

Sample Notes:**Samples for EMSL Kit 142127**

Liquid Scintillation ID	Location	Radon Activity pCi/L	Start	Stop	Temperature F	Humidity %	Sample Type
239735	17	0.5	4/1/2016	4/4/2016	70	50	Customer
381603378-0009			9:33:00 AM	6:34:00 AM			

Sample Notes:**Samples for EMSL Kit 142129**

Liquid Scintillation ID	Location	Radon Activity pCi/L	Start	Stop	Temperature F	Humidity %	Sample Type
239621	14	0.6	4/1/2016	4/4/2016	70	50	Customer
381603378-0010			9:34:00 AM	6:33:00 AM			

Sample Notes:

**EMSL Analytical, Inc.**

200 Route 130 North, Cinnaminson, NJ 08077

Phone/Fax: (800) 220-3675 / (856) 786-0327

<http://www.EMSL.com>cinnaminsonradonlab@emsl.com

EMSL Order: 381603378

CustomerID: PGCS62

CustomerPO:

ProjectID:

Attn: **Karen Bowlding**
Prince George's County School
13300 Old Marlboro Pike
Upper Marlboro, MD 20772

Phone: (301) 952-6559
 Fax: (301) 952-0346
 Received: 04/08/16 10:33 AM
 Analysis Date: 4/9/2016
 Collected: 4/1/2016

Project: **Dora Kennedy (Old Greenbelt MS)**

Test Site: **Dora Kennedy (Old Greenbelt MS)**
Greenbelt, MD 20770

Test Report: Radon in Air Test Results**Samples for EMSL Kit 142128**

Liquid Scintillation ID	Location	Radon Activity pCi/L	Start	Stop	Temperature F	Humidity %	Sample Type
239625	15	0.7	4/1/2016	4/4/2016	70	50	Customer
381603378-0011			9:35:00 AM	6:32:00 AM			

Sample Notes:

239856	15	0.5	4/1/2016	4/4/2016	70	50	Duplicate
381603378-0012			9:35:00 AM	6:32:00 AM			

Sample Notes:**Duplicate RPD = 33.3%****Samples for EMSL Kit 142126**

Liquid Scintillation ID	Location	Radon Activity pCi/L	Start	Stop	Temperature F	Humidity %	Sample Type
239698	12	0.4	4/1/2016	4/4/2016	70	50	Customer
381603378-0013			9:36:00 AM	6:31:00 AM			

Sample Notes:**Samples for EMSL Kit 142124**

Liquid Scintillation ID	Location	Radon Activity pCi/L	Start	Stop	Temperature F	Humidity %	Sample Type
239716	11	0.5	4/1/2016	4/4/2016	70	50	Customer
381603378-0014			9:37:00 AM	6:30:00 AM			

Sample Notes:

The radon test was performed using a liquid scintillation radon detector/s and counted on a liquid scintillation counter using approved EPA testing protocols for Radon in Air testing. The EPA recommends fixing your home if the average of two short-term tests taken in the lowest lived-in level of the home show radon levels that are equal to or greater than 4.0pCi/L.

The EPA recommends retesting your home every two years.

Please contact EMSL Analytical, Inc. or your State Health Department for further information.

All procedures used for generating this report are in complete accordance with the current EPA protocols for the analysis of Radon in Air.

Report Note



EMSL Analytical, Inc.

200 Route 130 North, Cinnaminson, NJ 08077
Phone/Fax: (800) 220-3675 / (856) 786-0327
<http://www.EMSL.com> cinnaminsonradonlab@emsl.com

EMSL Order: 381603378
CustomerID: PGCS62
CustomerPO:
ProjectID:

Attn: **Karen Bowlding**
Prince George's County School
13300 Old Marlboro Pike
Upper Marlboro, MD 20772

Phone: (301) 952-6559
Fax: (301) 952-0346
Received: 04/08/16 10:33 AM
Analysis Date: 4/9/2016
Collected: 4/1/2016

Project: **Dora Kennedy (Old Greenbelt MS)**

Test Site: **Dora Kennedy (Old Greenbelt MS)**
Greenbelt, MD 20770

Test Report: Radon in Air Test Results

Analyst(s)

Laura Freeman (14)

Laura Freeman, Interim Laboratory Manager &
Subash Rashat, New Jersey Radiation Specialist NJ MES 10152
or other approved signatory

In no event shall EMSL be liable for indirect, special, consequential, or incidental damages, including, but not limited to, damages for loss of profit or goodwill regardless of the negligence (either sole or concurrent) of EMSL and whether EMSL has been informed of the possibility of such damages, arising out of or in connection with EMSL's services thereunder or the delivery, use, reliance upon or interpretation of test results by client or any third party. We accept no legal responsibility for the purposes for which the client uses the test results. In no event shall EMSL be liable to a client or any third party, whether based upon theories of tort, contract or any other legal or equitable theory, in excess of the amount paid to EMSL by client thereunder. The test results meets all NELAC requirements unless otherwise specified. Accreditations: NRSB ARL6006, NJ DEP 03036, MEB 92525, PA 2573, IN 00455, IA L00032, RI RAS-024, ME 20200C, NE RMB-1083, NY ELAP 10872, NM 885-10L, FL RB2034, OH RL-39, NRPP #106178AL, KS-LB-0005

Samples analyzed by EMSL Analytical, Inc. Cinnaminson, NJ Accreditations: NRSB ARL6006, NJ DEP 03036, MEB 92525, PA 2573, IN 00455, IA L00032, RI RAS-024, ME 20200C, NE RMB-1083, NY ELAP 10872, NM 885-10L, FL RB2034, OH RL-39, NRPP #106178AL, KS-LB-0005. Subash Rashat certification #MES10152

Initial report from 04/15/2016 17:19:59

Please visit www.radontestinglab.com