

**EMSL Analytical, Inc.**

200 Route 130 North, Cinnaminson, NJ 08077
 Phone/Fax: (800) 220-3675 / (856) 786-0327
<http://www.EMSL.com> cinnaminsonradonlab@emsl.com

EMSL Order: 381603384
 CustomerID: PGCS62
 CustomerPO:
 ProjectID:

Attn: **Prince George's County School**
13300 Old Marlboro Pike
Upper Marlboro, MD 20772

Phone: (301) 952-6559
 Fax: (301) 952-0346
 Received: 04/08/16 10:33 AM
 Analysis Date: 4/11/2016
 Collected: 4/1/2016

Project: **Highland Park ES**

Test Site: **Highland Park ES**
Landover, MD 20785

Test Report: Radon in Air Test Results**Samples for EMSL Kit 143342**

Liquid Scintillation ID	Location	Radon Activity pCi/L	Start	Stop	Temperature F	Humidity %	Sample Type
241299	Room C-02	2.7	4/1/2016	4/4/2016	70	50	Customer
381603384-0001			10:58:00 AM	8:45:00 AM			

Sample Notes:

241594	Room C-02	-0.1	4/1/2016	4/4/2016	70	50	Duplicate
381603384-0002			10:58:00 AM	8:45:00 AM			

Sample Notes:**Duplicate RPD = 200%****Samples for EMSL Kit 143364**

Liquid Scintillation ID	Location	Radon Activity pCi/L	Start	Stop	Temperature F	Humidity %	Sample Type
241283	Main Office	0.7	4/1/2016	4/4/2016	70	50	Customer
381603384-0003			11:00:00 AM	8:43:00 AM			

Sample Notes:**Samples for EMSL Kit 143319**

Liquid Scintillation ID	Location	Radon Activity pCi/L	Start	Stop	Temperature F	Humidity %	Sample Type
241515	Room C-04	1.3	4/1/2016	4/4/2016	70	50	Customer
381603384-0004			11:05:00 AM	8:42:00 AM			

Sample Notes:**Samples for EMSL Kit 143350**

Liquid Scintillation ID	Location	Radon Activity pCi/L	Start	Stop	Temperature F	Humidity %	Sample Type
241232	Room C-06	1.5	4/1/2016	4/4/2016	70	50	Customer
381603384-0005			11:10:00 AM	8:40:00 AM			

Sample Notes:**Samples for EMSL Kit 143340**

Liquid Scintillation ID	Location	Radon Activity pCi/L	Start	Stop	Temperature F	Humidity %	Sample Type
241244	Room C-06	1.5	4/1/2016	4/4/2016	70	50	Customer
381603384-0006			11:13:00 AM	8:36:00 AM			

Sample Notes:

**EMSL Analytical, Inc.**

200 Route 130 North, Cinnaminson, NJ 08077
 Phone/Fax: (800) 220-3675 / (856) 786-0327
<http://www.EMSL.com> cinnaminsonradonlab@emsl.com

EMSL Order: 381603384
 CustomerID: PGCS62
 CustomerPO:
 ProjectID:

Attn: **Prince George's County School**
13300 Old Marlboro Pike
Upper Marlboro, MD 20772

Phone: (301) 952-6559
 Fax: (301) 952-0346
 Received: 04/08/16 10:33 AM
 Analysis Date: 4/11/2016
 Collected: 4/1/2016

Project: **Highland Park ES**

Test Site: **Highland Park ES**
Landover, MD 20785

Test Report: Radon in Air Test Results**Samples for EMSL Kit 143329**

Liquid Scintillation ID	Location	Radon Activity pCi/L	Start	Stop	Temperature F	Humidity %	Sample Type
241513	Room C-07	2.1	4/1/2016	4/4/2016	70	50	Customer
381603384-0007			11:15:00 AM	8:32:00 AM			

Sample Notes:

Samples for EMSL Kit 143363

Liquid Scintillation ID	Location	Radon Activity pCi/L	Start	Stop	Temperature F	Humidity %	Sample Type
241340	Room C-08		4/1/2016	4/4/2016	70	50	Customer
381603384-0008			11:20:00 AM	8:28:00 AM			

Sample Notes: Not Analyzed
 Radon device received open.

Samples for EMSL Kit 143349

Liquid Scintillation ID	Location	Radon Activity pCi/L	Start	Stop	Temperature F	Humidity %	Sample Type
241213	Room C-10	0.8	4/1/2016	4/4/2016	70	50	Customer
381603384-0009			11:25:00 AM	8:24:00 AM			

Sample Notes:

Samples for EMSL Kit 143197

Liquid Scintillation ID	Location	Radon Activity pCi/L	Start	Stop	Temperature F	Humidity %	Sample Type
241491	Room C-09	1.2	4/1/2016	4/4/2016	70	50	Customer
381603384-0010			11:30:00 AM	8:22:00 AM			

Sample Notes:

**EMSL Analytical, Inc.**

200 Route 130 North, Cinnaminson, NJ 08077

Phone/Fax: (800) 220-3675 / (856) 786-0327

<http://www.EMSL.com>cinnaminsonradonlab@emsl.com

EMSL Order: 381603384

CustomerID: PGCS62

CustomerPO:

ProjectID:

Attn: **Prince George's County School**
13300 Old Marlboro Pike
Upper Marlboro, MD 20772

Phone: (301) 952-6559
 Fax: (301) 952-0346
 Received: 04/08/16 10:33 AM
 Analysis Date: 4/11/2016
 Collected: 4/1/2016

Project: **Highland Park ES**

Test Site: **Highland Park ES**
Landover, MD 20785

Test Report: Radon in Air Test Results**Samples for EMSL Kit 143318**

Liquid Scintillation ID	Location	Radon Activity pCi/L	Start	Stop	Temperature F	Humidity %	Sample Type
241355	Room C-15	0.9	4/1/2016	4/4/2016	70	50	Customer
381603384-0011			11:33:00 AM	8:20:00 AM			

Sample Notes:

241545	Room C-15	-0.1	4/1/2016	4/4/2016	70	50	Duplicate
381603384-0012			11:33:00 AM	8:20:00 AM			

Sample Notes:**Duplicate RPD = 200%****Samples for EMSL Kit 143328**

Liquid Scintillation ID	Location	Radon Activity pCi/L	Start	Stop	Temperature F	Humidity %	Sample Type
241453	Room B-16	0.6	4/1/2016	4/4/2016	70	50	Customer
381603384-0013			11:36:00 AM	8:15:00 AM			

Sample Notes:

241604	Room B-16	-0.1	4/1/2016	4/4/2016	70	50	Duplicate
381603384-0014			11:36:00 AM	8:15:00 AM			

Sample Notes:**Duplicate RPD = 200%****Samples for EMSL Kit 143212**

Liquid Scintillation ID	Location	Radon Activity pCi/L	Start	Stop	Temperature F	Humidity %	Sample Type
241389	Room B-15	0.3	4/1/2016	4/4/2016	70	50	Customer
381603384-0015			11:40:00 AM	8:11:00 AM			

Sample Notes:

241465	Room B-15	-0.2	4/1/2016	4/4/2016	70	50	Duplicate
381603384-0016			11:40:00 AM	8:11:00 AM			

Sample Notes:**Duplicate RPD = 200%****Samples for EMSL Kit 143353**

Liquid Scintillation ID	Location	Radon Activity pCi/L	Start	Stop	Temperature F	Humidity %	Sample Type
241270	Room B-14	0.6	4/1/2016	4/4/2016	70	50	Customer
381603384-0017			11:45:00 AM	8:18:00 AM			

Sample Notes:

**EMSL Analytical, Inc.**

200 Route 130 North, Cinnaminson, NJ 08077
 Phone/Fax: (800) 220-3675 / (856) 786-0327
<http://www.EMSL.com> cinnaminsonradonlab@emsl.com

EMSL Order: 381603384
 CustomerID: PGCS62
 CustomerPO:
 ProjectID:

Attn: **Prince George's County School**
13300 Old Marlboro Pike
Upper Marlboro, MD 20772

Phone: (301) 952-6559
 Fax: (301) 952-0346
 Received: 04/08/16 10:33 AM
 Analysis Date: 4/11/2016
 Collected: 4/1/2016

Project: **Highland Park ES**

Test Site: **Highland Park ES**
Landover, MD 20785

Test Report: Radon in Air Test Results**Samples for EMSL Kit 143188**

Liquid Scintillation ID	Location	Radon Activity pCi/L	Start	Stop	Temperature F	Humidity %	Sample Type
241457	Room B-13	0.3	4/1/2016	4/4/2016	70	50	Customer
381603384-0018			11:48:00 AM	8:13:00 AM			

Sample Notes:

241499	Room B-13	-0.2	4/1/2016	4/4/2016	70	50	Duplicate
381603384-0019			11:48:00 AM	8:13:00 AM			

Sample Notes:**Duplicate RPD = 200%****Samples for EMSL Kit 143189**

Liquid Scintillation ID	Location	Radon Activity pCi/L	Start	Stop	Temperature F	Humidity %	Sample Type
241318	Room B-11	0.3	4/1/2016	4/4/2016	70	50	Customer
381603384-0020			11:50:00 AM	8:09:00 AM			

Sample Notes:**Samples for EMSL Kit 143195**

Liquid Scintillation ID	Location	Radon Activity pCi/L	Start	Stop	Temperature F	Humidity %	Sample Type
241448	Room B-10	-0.2	4/1/2016	4/4/2016	70	50	Customer
381603384-0021			11:55:00 AM	8:08:00 AM			

Sample Notes:

240277	Room B-10	0.7	4/1/2016	4/4/2016	70	50	Blank
381603384-0022			11:55:00 AM	8:08:00 AM			

Sample Notes:**Samples for EMSL Kit 143207**

Liquid Scintillation ID	Location	Radon Activity pCi/L	Start	Stop	Temperature F	Humidity %	Sample Type
241428	Room B-09	1	4/1/2016	4/4/2016	70	50	Customer
381603384-0023			12:00:00 PM	8:05:00 AM			

Sample Notes:



EMSL Analytical, Inc.

200 Route 130 North, Cinnaminson, NJ 08077
Phone/Fax: (800) 220-3675 / (856) 786-0327
<http://www.EMSL.com> cinnaminsonradonlab@emsl.com

EMSL Order: 381603384
CustomerID: PGCS62
CustomerPO:
ProjectID:

Attn: **Prince George's County School**
13300 Old Marlboro Pike
Upper Marlboro, MD 20772

Phone: (301) 952-6559
Fax: (301) 952-0346
Received: 04/08/16 10:33 AM
Analysis Date: 4/11/2016
Collected: 4/1/2016

Project: **Highland Park ES**

Test Site: **Highland Park ES**
Landover, MD 20785

Test Report: Radon in Air Test Results

Samples for EMSL Kit 143196

Liquid Scintillation ID	Location	Radon Activity pCi/L	Start	Stop	Temperature F	Humidity %	Sample Type
241444	Media Center	0.8	4/1/2016	4/4/2016	70	50	Customer
381603384-0024			12:05:00 PM	8:00:00 AM			

Sample Notes:

The radon test was performed using a liquid scintillation radon detector/s and counted on a liquid scintillation counter using approved EPA testing protocols for Radon in Air testing. The EPA recommends fixing your home if the average of two short-term tests taken in the lowest lived-in level of the home show radon levels that are equal to or greater than 4.0pCi/L. The EPA recommends retesting your home every two years.

Please contact EMSL Analytical, Inc. or your State Health Department for further information. All procedures used for generating this report are in complete accordance with the current EPA protocols for the analysis of Radon in Air.

Report Note

Analyst(s)

Laura Freeman (23)

Laura Freeman, Interim Laboratory Manager &
Subash Rashat, New Jersey Radiation Specialist NJ MES 10152
or other approved signatory

In no event shall EMSL be liable for indirect, special, consequential, or incidental damages, including, but not limited to, damages for loss of profit or goodwill regardless of the negligence (either sole or concurrent) of EMSL and whether EMSL has been informed of the possibility of such damages, arising out of or in connection with EMSL's services thereunder or the delivery, use, reliance upon or interpretation of test results by client or any third party. We accept no legal responsibility for the purposes for which the client uses the test results. In no event shall EMSL be liable to a client or any third party, whether based upon theories of tort, contract or any other legal or equitable theory, in excess of the amount paid to EMSL by client thereunder. The test results meets all NELAC requirements unless otherwise specified. Accreditations: NRSB ARL6006, NJ DEP 03036, MEB 92525, PA 2573, IN 00455, IA L00032, RI RAS-024, ME 20200C, NE RMB-1083, NY ELAP 10872, NM 885-10L, FL RB2034, OH RL-39, NRPP #106178AL, KS-LB-0005

Samples analyzed by EMSL Analytical, Inc. Cinnaminson, NJ Accreditations: NRSB ARL6006, NJ DEP 03036, MEB 92525, PA 2573, IN 00455, IA L00032, RI RAS-024, ME 20200C, NE RMB-1083, NY ELAP 10872, NM 885-10L, FL RB2034, OH RL-39, NRPP #106178AL, KS-LB-0005. Subash Rashat certification #MES10152

Initial report from 04/15/2016 16:29:10

Please visit www.radontestinglab.com