

**EMSL Analytical, Inc.**

200 Route 130 North, Cinnaminson, NJ 08077
 Phone/Fax: (800) 220-3675 / (856) 786-0327
<http://www.EMSL.com> cinnaminsonradonlab@emsl.com

EMSL Order: 381601787
 CustomerID: PGCS62
 CustomerPO: 608048
 ProjectID:

Attn: **Karen Bowlding**
Prince George's County School
13300 Old Marlboro Pike
Upper Marlboro, MD 20772

Phone: (301) 952-6559
 Fax: (301) 952-0346
 Received: 03/01/16 11:41 AM
 Analysis Date: 3/3/2016
 Collected: 2/26/2016

Project: **Kenilworth ES**

Test Site: **Kenilworth ES**
Bowie, MD 20715

Test Report: Radon in Air Test Results**Samples for EMSL Kit 139639**

Liquid Scintillation ID	Location	Radon Activity pCi/L	Start	Stop	Temperature F	Humidity %	Sample Type
234535	Main Office	0.5	2/26/2016	2/29/2016	70	50	Customer
381601787-0001			4:54:00 PM	7:16:00 AM			

Sample Notes:

Samples for EMSL Kit 139653

Liquid Scintillation ID	Location	Radon Activity pCi/L	Start	Stop	Temperature F	Humidity %	Sample Type
235371	Room 101	1.4	2/26/2016	2/29/2016	70	50	Customer
381601787-0002			4:57:00 PM	7:18:00 AM			

Sample Notes:

Samples for EMSL Kit 139652

Liquid Scintillation ID	Location	Radon Activity pCi/L	Start	Stop	Temperature F	Humidity %	Sample Type
235139	Room 102	0.9	2/26/2016	2/29/2016	70	50	Customer
381601787-0003			4:59:00 PM	7:19:00 AM			

Sample Notes:

235343	Room 102	1.1	2/26/2016	2/29/2016	70	50	Duplicate
381601787-0004			4:59:00 PM	7:19:00 AM			

Sample Notes:

Duplicate RPD = 20%

Samples for EMSL Kit 139649

Liquid Scintillation ID	Location	Radon Activity pCi/L	Start	Stop	Temperature F	Humidity %	Sample Type
234510	Room 106	4.1	2/26/2016	2/29/2016	70	50	Customer
381601787-0005			5:01:00 PM	7:20:00 AM			

Sample Notes:

Samples for EMSL Kit 139641

Liquid Scintillation ID	Location	Radon Activity pCi/L	Start	Stop	Temperature F	Humidity %	Sample Type
234555	Room 107	1.6	2/26/2016	2/29/2016	70	50	Customer
381601787-0006			5:04:00 PM	7:22:00 AM			

Sample Notes:

**EMSL Analytical, Inc.**

200 Route 130 North, Cinnaminson, NJ 08077
 Phone/Fax: (800) 220-3675 / (856) 786-0327
<http://www.EMSL.com> cinnaminsonradonlab@emsl.com

EMSL Order: 381601787
 CustomerID: PGCS62
 CustomerPO: 608048
 ProjectID:

Attn: **Karen Bowlding**
Prince George's County School
13300 Old Marlboro Pike
Upper Marlboro, MD 20772

Phone: (301) 952-6559
 Fax: (301) 952-0346
 Received: 03/01/16 11:41 AM
 Analysis Date: 3/3/2016
 Collected: 2/26/2016

Project: **Kenilworth ES**

Test Site: **Kenilworth ES**
Bowie, MD 20715

Test Report: Radon in Air Test Results**Samples for EMSL Kit 139650**

Liquid Scintillation ID	Location	Radon Activity pCi/L	Start	Stop	Temperature F	Humidity %	Sample Type
234513	Room 108	3.3	2/26/2016	2/29/2016	70	50	Customer
381601787-0007			5:06:00 PM	7:23:00 AM			

Sample Notes:

Samples for EMSL Kit 139640

Liquid Scintillation ID	Location	Radon Activity pCi/L	Start	Stop	Temperature F	Humidity %	Sample Type
234551	Room 108	1.5	2/26/2016	2/29/2016	70	50	Customer
381601787-0008			5:10:00 PM	7:27:00 AM			

Sample Notes:

Samples for EMSL Kit 139642

Liquid Scintillation ID	Location	Radon Activity pCi/L	Start	Stop	Temperature F	Humidity %	Sample Type
235134	Library	4.3	2/26/2016	2/29/2016	70	50	Customer
381601787-0009			5:12:00 PM	7:29:00 AM			

Sample Notes:

235221	Library	4.1	2/26/2016	2/29/2016	70	50	Duplicate
381601787-0010			5:12:00 PM	7:29:00 AM			

Sample Notes:

Duplicate RPD = 4.8%

Samples for EMSL Kit 139651

Liquid Scintillation ID	Location	Radon Activity pCi/L	Start	Stop	Temperature F	Humidity %	Sample Type
234505	Room 10	0.1	2/26/2016	2/29/2016	70	50	Customer
381601787-0011			5:15:00 PM	7:31:00 AM			

Sample Notes:

**EMSL Analytical, Inc.**

200 Route 130 North, Cinnaminson, NJ 08077
 Phone/Fax: (800) 220-3675 / (856) 786-0327
<http://www.EMSL.com> cinnaminsonradonlab@emsl.com

EMSL Order: 381601787
 CustomerID: PGCS62
 CustomerPO: 608048
 ProjectID:

Attn: **Karen Bowlding**
Prince George's County School
13300 Old Marlboro Pike
Upper Marlboro, MD 20772

Phone: (301) 952-6559
 Fax: (301) 952-0346
 Received: 03/01/16 11:41 AM
 Analysis Date: 3/3/2016
 Collected: 2/26/2016

Project: **Kenilworth ES**

Test Site: **Kenilworth ES**
Bowie, MD 20715

Test Report: Radon in Air Test Results**Samples for EMSL Kit 139648**

Liquid Scintillation ID	Location	Radon Activity pCi/L	Start	Stop	Temperature F	Humidity %	Sample Type
235159	Studio Room	13.3	2/26/2016	2/29/2016	70	50	Customer
381601787-0012			5:17:00 PM	7:34:00 AM			

Sample Notes:

235197	Studio Room	13.5	2/26/2016	2/29/2016	70	50	Duplicate
381601787-0013			5:17:00 PM	7:34:00 AM			

Sample Notes:

Duplicate RPD = 1.5%

Samples for EMSL Kit 139656

Liquid Scintillation ID	Location	Radon Activity pCi/L	Start	Stop	Temperature F	Humidity %	Sample Type
234502	B&A Office	0.2	2/26/2016	2/29/2016	70	50	Customer
381601787-0014			5:18:00 PM	7:32:00 AM			

Sample Notes:**Samples for EMSL Kit 139646**

Liquid Scintillation ID	Location	Radon Activity pCi/L	Start	Stop	Temperature F	Humidity %	Sample Type
234501	Nurse Office	0.6	2/26/2016	2/29/2016	70	50	Customer
381601787-0015			5:21:00 PM	7:36:00 AM			

Sample Notes:**Samples for EMSL Kit 139678**

Liquid Scintillation ID	Location	Radon Activity pCi/L	Start	Stop	Temperature F	Humidity %	Sample Type
236805	Stage	0.4	2/26/2016	2/29/2016	70	50	Customer
381601787-0016			5:26:00 PM	7:14:00 AM			

Sample Notes:

235259	Stage	0.5	2/26/2016	2/29/2016	70	50	Duplicate
381601787-0017			5:26:00 PM	7:14:00 AM			

Sample Notes:

Duplicate RPD = 22.2%



EMSL Analytical, Inc.

200 Route 130 North, Cinnaminson, NJ 08077

Phone/Fax: (800) 220-3675 / (856) 786-0327

<http://www.EMSL.com>

cinnaminsonradonlab@emsl.com

EMSL Order:	381601787
CustomerID:	PGCS62
CustomerPO:	608048
ProjectID:	

Attn: **Karen Bowlding**
Prince George's County School
13300 Old Marlboro Pike
Upper Marlboro, MD 20772

Phone: (301) 952-6559
 Fax: (301) 952-0346
 Received: 03/01/16 11:41 AM
 Analysis Date: 3/3/2016
 Collected: 2/26/2016

Project: **Kenilworth ES**

Test Site: **Kenilworth ES**
Bowie, MD 20715

Test Report: Radon in Air Test Results

The radon test was performed using a liquid scintillation radon detector/s and counted on a liquid scintillation counter using approved EPA testing protocols for Radon in Air testing. The EPA recommends fixing your home if the average of two short-term tests taken in the lowest lived-in level of the home show radon levels that are equal to or greater than 4.0pCi/L. The EPA recommends retesting your home every two years.



Please contact EMSL Analytical, Inc. or your State Health Department for further information.

All procedures used for generating this report are in complete accordance with the current EPA protocols for the analysis of Radon in Air.

Report Note

Analyst(s)

Tiffanie Cosgrove (17)

Laura Freeman, Interim Laboratory Manager &
 Subash Rashat, New Jersey Radiation Specialist NJ MES 10152
 or other approved signatory

In no event shall EMSL be liable for indirect, special, consequential, or incidental damages, including, but not limited to, damages for loss of profit or goodwill regardless of the negligence (either sole or concurrent) of EMSL and whether EMSL has been informed of the possibility of such damages, arising out of or in connection with EMSL's services thereunder or the delivery, use, reliance upon or interpretation of test results by client or any third party. We accept no legal responsibility for the purposes for which the client uses the test results. In no event shall EMSL be liable to a client or any third party, whether based upon theories of tort, contract or any other legal or equitable theory, in excess of the amount paid to EMSL by client thereunder. The test results meets all NELAC requirements unless otherwise specified. Accreditations: NRSB ARL6006, NJ DEP 03036, MEB 92525, PA 2573, IN 00455, IA L00032, RI RAS-024, ME 20200C, NE RMB-1083, NY ELAP 10872, NM 885-10L, FL RB2034, OH RL-39, NRPP #106178AL, KS-LB-0005

Samples analyzed by EMSL Analytical, Inc. Cinnaminson, NJ Accreditations: NRSB ARL6006, NJ DEP 03036, MEB 92525, PA 2573, IN 00455, IA L00032, RI RAS-024, ME 20200C, NE RMB-1083, NY ELAP 10872, NM 885-10L, FL RB2034, OH RL-39, NRPP #106178AL, KS-LB-0005. Subash Rashat certification #MES10152

Report Amended: 03/10/2016 12:17:35 Replaces the Inital Report 03/10/2016 12:15:39. Reason Code: Data Entry-Change to kit number

Please visit www.radontestinglab.com