



Architecture | Engineering | Construction

9220 Rumsey Road, Suite 100, Columbia, MD 21045
T: 410.992.3424 | F: 410.992.1837

December 14, 2020

Prince George's County Public Schools
13300 Old Marlboro Pike
Upper Marlboro, Maryland 20772
Attention: Mr. Alex Baylor

RE: Indoor Air Quality Assessment, Ardmore Elementary School
IFB: 022-19
ATI Project Number: 20-684

Dear Mr. Baylor:

Prince George's County Public Schools requested that ATI, Inc., conduct a proactive indoor air quality (IAQ) assessment at Ardmore Elementary School on November 30, 2020. Its key findings are enclosed in the Executive Summary on page three, and the official laboratory report for total fungal spore trap sampling is enclosed in Appendix A.

Thank you for the opportunity to provide Industrial Hygiene services for Prince George's County Public Schools. If you have any questions regarding this report, please contact us at (202) 643-4283.

Sincerely,
ATI, INC.

Courtney E. McCall
Project Manager

Nate Burgei, CIH, CSP
Certified Industrial Hygienist

Indoor Air Quality Assessment Report



Prince George's County Public Schools
Ardmore Elementary School
9301 Ardwick Ardmore Road
Springdale, Maryland 20774

Prepared for:

Prince George's County Public Schools
13300 Old Marlboro Pike
Upper Marlboro, Maryland 20772

December 14, 2020

Submitted by:



ATI Job # 20-684

Table of Contents

Table of Contents.....	1
1 Executive Summary	1
2 Assessment Methods.....	1
3 Visual Observations	2
4 Thermal Environmental Conditions for Human Occupancy.....	3
4.1 Temperature.....	3
4.2 Relative Humidity.....	3
4.3 Carbon Dioxide.....	4
4.4 Carbon Monoxide.....	5
5 Total Fungal Air Sampling Results.....	5
6 Summary of Findings	6

List of Tables

Table 1: Visual Observations and Sampling Locations.....	2
Table 2: Temperature	3
Table 3: Relative Humidity	4
Table 4: Carbon Dioxide	4
Table 5: Carbon Monoxide.....	5

Appendices

- Appendix A: Laboratory Report and Chain of Custody
- Appendix B: Instrument Calibration Records

Abbreviations and Acronyms

AHU	Air-Handling Unit
AIHA	American Industrial Hygiene Association
ASHRAE	American Society of Heating, Refrigerating and Air-Conditioning Engineers
ASTM	American Society for Testing and Materials
CO	Carbon Monoxide
CO₂	Carbon Dioxide
EMLAP	Environmental Microbiology Laboratory Accreditation Program
HVAC	Heating, Ventilating, And Air-Conditioning
IAQ	Indoor Air Quality
NIST	National Institute for Standards and Technology
NVLAP	National Voluntary Laboratory Accreditation Program
RH	Relative Humidity
Rev.	Revision

Abbreviations involving scientific volume and measurements involving media or water sampling

Counts/m³	Mold spores per cubic meter of air
LPM	Liters Per Minute
NTE	Not to exceed
°F	degree Fahrenheit
PPM	Parts Per Million

1 Executive Summary

ATI conducted a proactive Indoor Air Quality (IAQ) assessment on November 30, 2020, at Ardmore Elementary School, located at 9301 Ardwick Ardmore Road, Springdale, MD 20774.

The assessment included a visual assessment of randomly selected classrooms and other frequently occupied spaces, such as the cafeteria, the main office, and classrooms, for potential IAQ contributors and pathways. As part of the assessment, ATI measured common IAQ comfort parameters, including temperature, relative humidity, carbon dioxide, and carbon monoxide using direct reading instruments. Also, ATI collected total fungal air samples on spore trap cassettes for microbiological analysis.

The following is a summary of the key findings from this assessment:

1. Four of the tested spaces had a temperature greater than the ASHRAE recommended winter range of 68-75°F.
2. The relative humidity in all tested spaces was less than the ASHRAE guidelines of <65%.
3. Carbon dioxide concentrations in one tested space was greater than the ASHRAE limit for carbon dioxide, which was 1,098 parts per million (PPM) for the day of the assessment.
4. Carbon monoxide concentrations were less than the IAQ meter's detection limit throughout the tested spaces.
5. The sampling results suggest that significant indoor amplification of mold was not present. While concentrations of *Aspergillus/Penicillium* and *Myxomyces* detected in certain tested rooms exceeded the ambient sample, the indoor concentrations were low, and not considered unusual for an occupied space.

2 Assessment Methods

Mikal Frater of ATI, Inc. conducted a visual assessment and air sampling on November 30, 2020. Sampled rooms were randomly selected and accounted for approximately 10% of classrooms or a minimum of five samples. Ms. Frater documented visual observations at the time she collected the air samples. ATI references the American Society of Heating, Refrigerating, and Air-Conditioning Engineers (ASHRAE) *Standard 62.1 – 2016* and *ASHRAE Standard 55 – 2017* when providing IAQ services to clients. ASHRAE is an industry leader on energy efficiency and indoor air quality.

All measurements and air samples were collected between three-six feet from floor elevation, which represents a typical breathing zone, and away from air-supply and return diffusers. Real-time direct readings for temperature, relative humidity, carbon dioxide (CO₂), and carbon monoxide (CO), were measured with a calibrated TSI Q-Trak 7575-X Meter and attached 982 Probe.

Total fungal air samples were collected with a Buck BioAire High-Volume Sampling Pump on Zefon Air-O-Cell spore-trap cassettes at a flow rate of 15 liters per minute for five minutes, for a sample volume of 75 liters. EMSL Analytical, Inc. of Beltsville, MD analyzed the samples using direct microscopic examination per ASTM D7391-09, which counts both viable and non-viable mold spores and particulates, which combined yields *total fungal* results. EMSL participates in the National Institute of Standards and Technology's (NIST) National Voluntary Laboratory Accreditation Program (NVLAP) for general laboratory performance and management, and the American Industrial Hygiene Association (AIHA) for Environmental Microbial Laboratory Accreditation Program (EMLAP). The EMSL laboratory reports are included in Appendix A.

3 Visual Observations

Table 1 lists the areas, conditions, observations, and other pertinent details related to this IAQ assessment. On the date of the sampling event, few occupants were present in the school because of the COVID-19 global pandemic.

Table 1: Visual Observations and Sampling Locations

Sample Location	Observations
Parking Lot – Outside	<ul style="list-style-type: none"> • Heavy rain • Cloudy skies • Light foot and vehicle traffic observed
Main Office	<ul style="list-style-type: none"> • Five occupants in the area during sampling • No odors, stained ceiling tiles, or visible mold growth observed • Door to corridor closed • One air diffuser in this space • Trace dust accumulation in this space • Space is approximately 224 ft.²
Computer Lab Room 20	<ul style="list-style-type: none"> • No odors, stained ceiling tiles, or visible mold growth observed • Two occupants in the area during sampling • Two returns in this space • Univent along wall – heat ON • Door to corridor ajar • Stained glass tiles along window wall • Friedrich A/C unit OFF during sampling • Shrubbery on outer end of A/C unit • Space is approximately 936 ft.²
Room 25	<ul style="list-style-type: none"> • No odors or visible mold growth observed • One occupant in the area during sampling • Light brown stained ceiling tile near front of room • Older Friedrich A/C unit OFF but noticeable dust accumulation present • Chalkboard replaced – from previous assessment • Two oscillating fans OFF (no front grid panel) • Space is approximately 1,534 ft.²
Room 33	<ul style="list-style-type: none"> • One occupant in the area during sampling • One air return in space • Four air diffusers in space • Two older Friedrich A/C units OFF during sampling • One oscillating fan OFF during sampling (no front cover) • Lot of storage/books/stacked materials in this space • Trace dust accumulation on A/C vents • Space is approximately 986 ft.²
Cafeteria	<ul style="list-style-type: none"> • No odors, stained ceiling tiles, or visible mold growth observed • Three occupants in area during sampling • Door to corridor open

Sample Location	Observations
	<ul style="list-style-type: none"> Four newer Friedrich A/C units OFF during sampling Space is approximately 2,400 ft.²

4 Thermal Environmental Conditions for Human Occupancy

ASHRAE *Standard 55-2017, Thermal Environmental Conditions for Human Occupancy*, addresses thermal comfort in an office environment, which means that an employee wearing a normal amount of clothing feels neither too cold nor too warm. This standard discusses thermal comfort within the context of air temperature, humidity, and air movement and provides recommended ranges for temperature and humidity that are intended to satisfy 80% of occupants. The recommended ASHRAE ranges are referenced below by each comfort parameter.

4.1 Temperature

The ASHRAE standard establishes a winter comfort range of between 68°F and 75°F and a summer range of between 73°F and 79°F. The temperatures measured during the November 30, 2020, assessment are summarized in Table 2. As indicated by the data in the table, temperatures in the school averaged between 73°F and 77°F, with four locations reporting greater than the ASHRAE recommended winter range.

Table 2: Temperature

Sample Location	11/30/2020 °F			ASHRAE Standard °F
	Min	Max	Average	
Outdoors	63	65	64	N/A
Indoors				
Main Office	76	77	77	68-75°F
Computer Lab Room 20	77	78	78	68-75°F
Room 25	77	77	77	68-75°F
Room 33	76	76	76	68-75°F
Cafeteria	72	73	73	68-75°F

4.2 Relative Humidity

Relative humidity is a key factor for mold growth. Mold has the potential of growing on suitable surfaces with humidity levels above 65%. ASHRAE *Standard 62.1-2016, Ventilation for Acceptable Indoor Air Quality*, recommends a maximum indoor relative humidity of 65% to prevent condensation of moisture on surfaces. Relative humidity below 30% may result in drying of occupants' mucous membranes and skin. Relative humidity measurements are summarized in Table 3. The average relative humidity ranged between 43% and 57%, with all tested locations measuring less than the ASHRAE maximum recommendation of 65% relative humidity.

Table 3: Relative Humidity

Sample Location	11/30/2020 (% RH)			ASHRAE Standard (% RH)
	Min	Max	Average	
Outdoors	85	96	91	N/A
Indoors				
Main Office	57	57	57	< 65
Computer Lab Room 20	50	50	50	< 65
Room 25	42	43	43	< 65
Room 33	48	50	49	< 65
Cafeteria	56	56	56	< 65

4.3 Carbon Dioxide

Carbon dioxide concentrations within an occupied building are a standard method used to gauge the efficiency of ventilation systems. Carbon dioxide is a by-product of human respiration and does not pose an acute health hazard alone. Elevated concentrations may suggest that insufficient fresh air is being supplied to an occupied space and/or that the ventilation system does not provide a sufficient rate of air exchange.

Research has indicated that buildings with adequately operating ventilation systems are able to remove odors generated by activities in an indoor office environment efficiently. ASHRAE *Standard 62.1-2016* states that comfort (odor) criteria with respect to human bioeffluents are likely to be satisfied if the ventilation can maintain indoor carbon dioxide concentrations less than 700 parts per million (ppm) greater than the outdoor air concentration. Typically, outdoor carbon dioxide concentrations range from 300-450 ppm, with the higher range typically found in urban areas during peak rush hour.

Carbon dioxide concentrations are summarized in Table 4. On the day of the assessment, the average outdoor carbon dioxide concentration was 398 ppm, which calculates to a maximum indoor concentration of 1,098 ppm (700 + 398). One tested location indoors was greater than the recommended maximum for the day of the assessment, suggesting that insufficient fresh make-up air was being supplied to the space at the time of the assessment.

Table 4: Carbon Dioxide

Sample Location	11/30/2020 Concentration (parts per million)			ASHRAE Standard (ppm) NTE
	Min	Max	Average	
Outdoors	396	400	398	N/A
Indoors				
Main Office	1,102	1,126	1,114	1,098
Computer Lab Room 20	460	474	467	1,098
Room 25	446	446	446	1,098
Room 33	442	450	446	1,098
Cafeteria	433	453	443	1,098

4.4 Carbon Monoxide

Carbon monoxide is a colorless and odorless gas produced by the incomplete combustion of carbon containing fuels. Oil, gasoline, diesel fuels, wood, coke, and coal are the major sources of carbon monoxide. ASHRAE recommends that carbon monoxide not exceed nine ppm indoors over an eight-hour time-weighted average. ATI measured carbon monoxide concentrations using a TSI Q-Trak model number 7575-X with an attached IAQ probe (model number 982). The instrument’s carbon monoxide sensor has an error range of ± 3% of the reading or three (3) ppm, whichever is greater. As indicated by the data in Table 5, carbon monoxide concentrations were less than the Q-Trak’s detection limit throughout the school.

Table 5: Carbon Monoxide

Sample Location	11/30/2020 Concentration (parts per million)			ASHRAE Standard (ppm)
	Min	Max	Average	
Outdoors	<3	<3	<3	N/A
Inside				
Main Office	<3	<3	<3	< 9
Computer Lab Room 20	<3	<3	<3	< 9
Room 25	<3	<3	<3	< 9
Room 33	<3	<3	<3	< 9
Cafeteria	<3	<3	<3	< 9

5 Total Fungal Air Sampling Results

Mold is carried indoors through building entrances, open windows, loading docks, foot traffic into buildings, and the HVAC system. To thrive indoors, mold requires a food source, proper temperature and humidity to foster its growth.

The November 30, 2020 mold assessments sampled air using spore trap cassettes in randomly selected classrooms and other areas throughout the facility. These cassettes collect both viable spores, those capable of producing more fungal colonies, and non-viable spores, which cannot reproduce. Based upon recognized industry practices, indoor mold concentrations are compared with those detected outdoors, which are also known as ambient or baseline samples.

In normal circumstances, the diversity of spores identified indoors and outdoors should be similar with some exceptions. The high concentration of one or two species of fungal spores identified indoors and the absence of the same species outdoors can indicate a moisture problem with the potential to degrade the air quality. Fungi species present indoors are typically found at levels ranging from approximately 10-50% of their levels in the outdoor air, reflecting the filtering by the building’s HVAC system.

The results suggest that the indoor concentrations were generally favorable compared to the outdoor concentrations. The total ambient spore concentration was 92,910 counts/m³, and all tested rooms had spore concentrations less than the ambient total. All tested rooms had basidiospore concentrations greater than 1,000 counts/m³ but less than the outdoor concentration. Because basidiospores are typically associated with outdoor origin, the presence of basidiospores in concentrations greater than 1,000 counts/m³ suggests that unfiltered outdoor entered the space, such as through an open window or it bypassed the HVAC filtration. Basidiospores can be an allergen to some individuals, so the spaces should be cleaned if occupants express allergic responses in these rooms, especially Room 33 which had a basidiospore concentration of 21,600 spore counts/m³.

Other tested rooms had relatively low concentrations of spores that were not detected in the ambient sample, such as *Myxomycetes* and *Aspergillus/Penicillium*. *Myxomycetes* concentrations did not exceed 300 counts/m³ in any tested space, and *Aspergillus/Penicillium*, which is known to cause allergic reactions in certain people, did not exceed 100 counts/m³ in any tested space. The low concentrations of these spores indoors do not suggest noteworthy amplification and are not considered unusual for an occupied indoor space.

The official laboratory report with spore trap samples collected on November 30, 2020, is presented in Appendix A.

6 Summary of Findings

1. Four of the tested spaces had a temperature greater than the ASHRAE recommended winter range of 68-75°F.
2. The relative humidity in all tested spaces was less than the ASHRAE guidelines of <65%.
3. Carbon dioxide concentrations in one tested space was greater than the ASHRAE limit for carbon dioxide, which was 1,098 parts per million (PPM) for the day of the assessment.
4. Carbon monoxide concentrations were less than the IAQ meter's detection limit throughout the tested spaces.
5. The sampling results suggest that significant indoor amplification of mold was not present. While concentrations of *Aspergillus/Penicillium* and *Myxomycetes* detected in certain tested rooms exceeded the ambient sample, the indoor concentrations were low, and not considered unusual for an occupied space.

We appreciate the opportunity to provide these IAQ testing services for you. If you have any questions, please contact us at (202) 643-4283.

Best,
ATI, INC.



Courtney E. McCall
Project Manager



Nate Burgei, CIH, CSP
Certified Industrial Hygienist

Appendix A: Laboratory Report and Chain of Custody



EMSL Analytical, Inc.

5221 Militia Hill Road Plymouth Meeting, PA 19462
Tel/Fax: (610) 828-3102 / (610) 828-3122
<http://www.EMSL.com> / plymouthmeetinglab@emsl.com

EMSL Order: 182003848
Customer ID: ATII25A
Customer PO:
Project ID:

Attention: Mikal Frater
ATI
4221 Forbes Blvd
Suite 250
Lanham, MD 20706
Project: PGPCS - Ardmore ES

Phone: (202) 832-1433
Fax:
Collected Date: 11/30/2020
Received Date: 11/30/2020 04:53 PM
Analyzed Date: 12/04/2020

Test Report: Air-O-Cell™ Analysis of Fungal Spores & Particulates by Optical Microscopy (Methods MICRO-SOP-201, ASTM D7391)

Lab Sample Number:	182003848-0001			182003848-0002			182003848-0003		
Client Sample ID:	20-684 01			20-684 02			20-684 03		
Volume (L):	75						75		
Sample Location:	Outside Parking Lot			Field Blank			Main Office		
Spore Types	Raw Count	Count/M ³	% of Total	Raw Count	Count/M ³	% of Total	Raw Count	Count/M ³	% of Total
Alternaria (Ulocladium)	-	-	-	-	-	-	-	-	-
Ascospores	37	1600	1.7	-	-	-	1	40	2.2
Aspergillus/Penicillium	-	-	-	-	-	-	2	80	4.3
Basidiospores	2130	89900	96.8	-	-	-	38	1600	87
Bipolaris++	-	-	-	-	-	-	-	-	-
Chaetomium	-	-	-	-	-	-	-	-	-
Cladosporium	25	1100	1.2	-	-	-	1	40	2.2
Curvularia	-	-	-	-	-	-	-	-	-
Epicoccum	-	-	-	-	-	-	-	-	-
Fusarium	-	-	-	-	-	-	-	-	-
Ganoderma	-	-	-	-	-	-	-	-	-
Myxomycetes++	8	300	0.3	-	-	-	2	80	4.3
Pithomyces++	-	-	-	-	-	-	-	-	-
Rust	1*	10*	0	-	-	-	-	-	-
Scopulariopsis/Microascus	-	-	-	-	-	-	-	-	-
Stachybotrys/Memnoniella	-	-	-	-	-	-	-	-	-
Unidentifiable Spores	-	-	-	-	-	-	-	-	-
Zygomycetes	-	-	-	-	-	-	-	-	-
Total Fungi	2201	92910	100	-	No Trace	-	44	1840	100
Hyphal Fragment	-	-	-	-	-	-	-	-	-
Insect Fragment	-	-	-	-	-	-	-	-	-
Pollen	-	-	-	-	-	-	-	-	-
Analyt. Sensitivity 600x	-	42	-	-	0	-	-	42	-
Analyt. Sensitivity 300x	-	13*	-	-	0*	-	-	13*	-
Skin Fragments (1-4)	-	1	-	-	-	-	-	3	-
Fibrous Particulate (1-4)	-	1	-	-	-	-	-	1	-
Background (1-5)	-	1	-	-	-	-	-	1	-

++ Includes other spores with similar morphology; see EMSL's fungal glossary for each specific category.

Kevin Ream, Laboratory Manager
or other Approved Signatory

EMSL maintains liability limited to cost of analysis. Interpretation and use of test results are the responsibility of the client. This report relates only to the samples reported above, and may not be reproduced, except in full, without written approval by EMSL. EMSL bears no responsibility for sample collection activities or analytical method limitations. The report reflects the samples as received. Results are generated from the field sampling data (sampling volumes and areas, locations, etc.) provided by the client on the Chain of Custody. Samples are within quality control criteria and met method specifications unless otherwise noted. High levels of background particulate can obscure spores and other particulates, leading to underestimation. Background levels of 5 indicate an overloading of background particulates, prohibiting accurate detection and quantification. Present = Spores detected on overloaded samples. Results are not blank corrected unless otherwise noted. The detection limit is equal to one fungal spore, structure, pollen, fiber particle or insect fragment. "*" Denotes particles found at 300X. "-" Denotes not detected. Due to method stopping rules, raw counts in excess of 100 are extrapolated based on the percentage analyzed.
Samples analyzed by EMSL Analytical, Inc. Plymouth Meeting, PA AIHA-LAP, LLC-EMLAP Accredited #178659

Initial report from: 12/04/2020 12:39 PM

For information on the fungi listed in this report, please visit the Resources section at www.emsl.com



EMSL Analytical, Inc.

5221 Militia Hill Road Plymouth Meeting, PA 19462
Tel/Fax: (610) 828-3102 / (610) 828-3122
<http://www.EMSL.com> / plymouthmeetinglab@emsl.com

EMSL Order: 182003848
Customer ID: ATII25A
Customer PO:
Project ID:

Attention: Mikal Frater
ATI
4221 Forbes Blvd
Suite 250
Lanham, MD 20706
Project: PGPCS - Ardmore ES

Phone: (202) 832-1433
Fax:
Collected Date: 11/30/2020
Received Date: 11/30/2020 04:53 PM
Analyzed Date: 12/04/2020

Test Report: Air-O-Cell™ Analysis of Fungal Spores & Particulates by Optical Microscopy (Methods MICRO-SOP-201, ASTM D7391)

Lab Sample Number: Client Sample ID: Volume (L): Sample Location:	182003848-0004 20-684 04 75 Computer Lab Room 20			182003848-0005 20-684 05 75 Room 25			182003848-0006 20-684 06 75 Room 33			
	Spore Types	Raw Count	Count/M³	% of Total	Raw Count	Count/M³	% of Total	Raw Count	Count/M³	% of Total
Alternaria (Ulocladium)	-	-	-	-	-	-	-	-	-	-
Ascospores	3	100	1.8	1*	10*	0.5	8	300	1.3	
Aspergillus/Penicillium	3	100	1.8	-	-	-	1	40	0.2	
Basidiospores	119	5020	90.8	47	2000	99.5	511	21600	96.9	
Bipolaris++	-	-	-	-	-	-	-	-	-	
Chaetomium	-	-	-	-	-	-	-	-	-	
Cladosporium	6	300	5.4	-	-	-	6	300	1.3	
Curvularia	-	-	-	-	-	-	-	-	-	
Epicoccum	-	-	-	-	-	-	-	-	-	
Fusarium	-	-	-	-	-	-	-	-	-	
Ganoderma	-	-	-	-	-	-	-	-	-	
Myxomycetes++	1*	10*	0.2	-	-	-	1	40	0.2	
Pithomyces++	-	-	-	-	-	-	-	-	-	
Rust	-	-	-	-	-	-	-	-	-	
Scopulariopsis/Microascus	-	-	-	-	-	-	-	-	-	
Stachybotrys/Memnoniella	-	-	-	-	-	-	-	-	-	
Unidentifiable Spores	-	-	-	-	-	-	-	-	-	
Zygomycetes	-	-	-	-	-	-	-	-	-	
Total Fungi	132	5530	100	48	2010	100	527	22280	100	
Hyphal Fragment	-	-	-	-	-	-	-	-	-	
Insect Fragment	-	-	-	-	-	-	-	-	-	
Pollen	-	-	-	-	-	-	-	-	-	
Analyt. Sensitivity 600x	-	42	-	-	42	-	-	42	-	
Analyt. Sensitivity 300x	-	13*	-	-	13*	-	-	13*	-	
Skin Fragments (1-4)	-	2	-	-	1	-	-	1	-	
Fibrous Particulate (1-4)	-	1	-	-	1	-	-	1	-	
Background (1-5)	-	1	-	-	1	-	-	1	-	

++ Includes other spores with similar morphology; see EMSL's fungal glossary for each specific category.

Kevin Ream, Laboratory Manager
or other Approved Signatory

EMSL maintains liability limited to cost of analysis. Interpretation and use of test results are the responsibility of the client. This report relates only to the samples reported above, and may not be reproduced, except in full, without written approval by EMSL. EMSL bears no responsibility for sample collection activities or analytical method limitations. The report reflects the samples as received. Results are generated from the field sampling data (sampling volumes and areas, locations, etc.) provided by the client on the Chain of Custody. Samples are within quality control criteria and met method specifications unless otherwise noted. High levels of background particulate can obscure spores and other particulates, leading to underestimation. Background levels of 5 indicate an overloading of background particulates, prohibiting accurate detection and quantification. Present = Spores detected on overloaded samples. Results are not blank corrected unless otherwise noted. The detection limit is equal to one fungal spore, structure, pollen, fiber particle or insect fragment. "*" Denotes particles found at 300X. "-" Denotes not detected. Due to method stopping rules, raw counts in excess of 100 are extrapolated based on the percentage analyzed.
Samples analyzed by EMSL Analytical, Inc. Plymouth Meeting, PA AIHA-LAP, LLC-EMLAP Accredited #178659

Initial report from: 12/04/2020 12:39 PM

For information on the fungi listed in this report, please visit the Resources section at www.emsl.com



EMSL Analytical, Inc.

5221 Militia Hill Road Plymouth Meeting, PA 19462
Tel/Fax: (610) 828-3102 / (610) 828-3122
<http://www.EMSL.com> / plymouthmeetinglab@emsl.com

EMSL Order: 182003848
Customer ID: ATII25A
Customer PO:
Project ID:

Attention: Mikal Frater
ATI
4221 Forbes Blvd
Suite 250
Lanham, MD 20706
Project: PGPCS - Ardmore ES

Phone: (202) 832-1433
Fax:
Collected Date: 11/30/2020
Received Date: 11/30/2020 04:53 PM
Analyzed Date: 12/04/2020

Test Report: Air-O-Cell™ Analysis of Fungal Spores & Particulates by Optical Microscopy (Methods MICRO-SOP-201, ASTM D7391)

Lab Sample Number:	182003848-0007		
Client Sample ID:	20-684 07		
Volume (L):	75		
Sample Location:	Cafeteria		
Spore Types	Raw Count	Count/M³	% of Total
Alternaria (Ulocladium)	-	-	-
Ascospores	8	300	6.9
Aspergillus/Penicillium	3*	40*	0.9
Basidiospores	94	4000	91.7
Bipolaris++	-	-	-
Chaetomium	-	-	-
Cladosporium	1*	10*	0.2
Curvularia	-	-	-
Epicoccum	-	-	-
Fusarium	-	-	-
Ganoderma	-	-	-
Myxomycetes++	1*	10*	0.2
Pithomyces++	-	-	-
Rust	-	-	-
Scopulariopsis/Microascus	-	-	-
Stachybotrys/Memnoniella	-	-	-
Unidentifiable Spores	-	-	-
Zygomycetes	-	-	-
Total Fungi	107	4360	100
Hyphal Fragment	-	-	-
Insect Fragment	-	-	-
Pollen	-	-	-
Analyt. Sensitivity 600x	-	42	-
Analyt. Sensitivity 300x	-	13*	-
Skin Fragments (1-4)	-	1	-
Fibrous Particulate (1-4)	-	1	-
Background (1-5)	-	1	-

++ Includes other spores with similar morphology; see EMSL's fungal glossary for each specific category.

Kevin Ream, Laboratory Manager
or other Approved Signatory

EMSL maintains liability limited to cost of analysis. Interpretation and use of test results are the responsibility of the client. This report relates only to the samples reported above, and may not be reproduced, except in full, without written approval by EMSL. EMSL bears no responsibility for sample collection activities or analytical method limitations. The report reflects the samples as received. Results are generated from the field sampling data (sampling volumes and areas, locations, etc.) provided by the client on the Chain of Custody. Samples are within quality control criteria and met method specifications unless otherwise noted. High levels of background particulate can obscure spores and other particulates, leading to underestimation. Background levels of 5 indicate an overloading of background particulates, prohibiting accurate detection and quantification. Present = Spores detected on overloaded samples. Results are not blank corrected unless otherwise noted. The detection limit is equal to one fungal spore, structure, pollen, fiber particle or insect fragment. "*" Denotes particles found at 300X. "-" Denotes not detected. Due to method stopping rules, raw counts in excess of 100 are extrapolated based on the percentage analyzed.
Samples analyzed by EMSL Analytical, Inc. Plymouth Meeting, PA AIHA-LAP, LLC-EMLAP Accredited #178659

Initial report from: 12/04/2020 12:39 PM

For information on the fungi listed in this report, please visit the Resources section at www.emsl.com



Microbiology Chain of Custody

EMSL Order Number (Lab Use Only):

182003848

EMSL ANALYTICAL, INC.
 200 ROUTE 130 NORTH
 CINNAMINSON, NJ 08077
 PHONE: (800) 220-3675
 FAX: (856) 786-0262

Company Name: ATI, Inc			EMSL-Bill to: <input type="checkbox"/> Same <input type="checkbox"/> Different if Bill to is Different note instructions in Comments				
Street: 4221 Rumsey Road, Suite 250			Third Party Billing requires written authorization from third party.				
City: Lanham	State/Province: MD	Zip/Postal Code: 20706	Country:				
Report To (Name): Mikal Frater			Telephone #: 202-558-7489				
Email Address: Mikal@atiinc.com / carmey@atiinc.com			Fax #:		Purchase Order:		
Project Name/Number: PGCPS - Ardmore ES			Please Provide Results: <input type="checkbox"/> Fax <input checked="" type="checkbox"/> Email				
U.S. State Samples Taken:		Project Zip Code:	Connecticut Samples: <input checked="" type="checkbox"/> Commercial <input type="checkbox"/> Residential				
Sterile, Sodium Thiosulfate Preserved Bottle Used: <input type="checkbox"/> Biocide Used in Source (specify): <input type="checkbox"/>							
Public Water Supply Samples: <input type="checkbox"/> Note: All results may automatically be reported to DOH if required by state.							
Turnaround Time (TAT) Options - Please Check							
<input type="checkbox"/> 3 Hour	<input type="checkbox"/> 6 Hour	<input type="checkbox"/> 24 Hour	<input type="checkbox"/> 48 Hour	<input type="checkbox"/> 72 Hour	<input type="checkbox"/> 96 Hour	<input checked="" type="checkbox"/> 1 Week	<input type="checkbox"/> 2 Week
Microbiology Test Codes							
M001 Air-O-Cell M030 Micro 5 M041 Fungal Direct Examination M169 Pollen ID & Enumeration M280 Dust Characterization Level-1 M281 Dust Characterization Level-2 M005 Viable Fungi- Air Samples (Genus ID & Count) M006 Viable Fungi- Air Samples (Includes Penicillium, Aspergillus, Cladosporium, Stachybotrys Species ID & Count) M007 Culturable fungi - Surface Samples (Genus ID & Count) M008 Culturable fungi - Surface Samples (Includes Penicillium, Aspergillus, Cladosporium, Stachybotrys Species ID & Count) M009 Bacteria Culture Gram Stain & Count M010 Bacteria Count & ID - 3 Most Prominent M011 Bacteria Count & ID - 5 Most Prominent		M174 MoldSnap M032 Allergenco-D M012 Pseudomonas aeruginosa (PIA***) M024 Pseudomonas aeruginosa (MFT*) M015 Heterotrophic Plate Count M017 Total Coliform & E. coli (Colilert PIA***) M018 Total Coliform & E. coli (MFT*) M114 Total Coliform & E. coli Enumeration (Colilert MPN**) M019 Fecal Coliform (MFT*) M020 Fecal Streptococcus (MFT*) M029 Enterococci (MFT*) M129 Enterococci (Enterolert PIA***) M180 Real Time qPCR-ERMI 36 Panel M025 Sewage Screen -Water (MFT*)		M115 Sewage Screen - Water (PIA***) M116 Sewage Screen - Water (MPN**) M117 Sewage Screen - Swab (PIA***) M013 Sewage Screen - Swab (MFT*) M133 Methicillin-resistant Staph. aureus (MRSA) M031 Rapid-growing non-TB Mycobacteria Detection & Enumeration M014 Endotoxin Analysis M044 Group Allergen (Cat, Dog, Cockroach, Dust Mite) Other See Analytical Price Guide Legionella Analysis Please use EMSL Legionella COC			
*MFT= Membrane Filtration Technique **MPN= Most Probable Number ***PIA= Presence/Absence							
Name of Sampler: Brian Chapman & Mikal Frater			Signature of Sampler: <i>Mikal Frater</i>				
Sample #	Sample Location/Description	Sample Type	Potable/ NonPotable (Only for Waters)	Test Code	Volume/ Area	Date/Time Collected	
20-684 01	Outside Parking Lot	Air	<input type="checkbox"/> P <input type="checkbox"/> NP	M001	75L	11/30 10:19	
20-684 02	Field Blank	Air	<input type="checkbox"/> P <input type="checkbox"/> NP	M001	75L		
20-684 03	Main Office	Air	<input type="checkbox"/> P <input type="checkbox"/> NP	M001	75L	11/30 11:13	
20-684 04	Computer Lab Room 20	Air	<input type="checkbox"/> P <input type="checkbox"/> NP	M001	75L	11/30 10:35	
20-684 05	Room 25	Air	<input type="checkbox"/> P <input type="checkbox"/> NP	M001	75L	11/30 10:42	
Client Sample # (s): - 7		Total # of Samples: 7		Samples Received/Checked? Yes/No (Lab Use Only)			
Relinquished (Client): <i>L. Somerville Drop Box</i>			Date: 11/30/20		Time: 4:10 pm		
Received (Lab): <i>L. Somerville Drop Box</i>			Date:		Time:		
Comments/Special Instructions:							

EMSL Analytical, Inc.'s Laboratory Terms and Conditions are incorporated into this chain of custody by reference in their entirety. Submission of samples to EMSL Analytical, Inc. constitutes acceptance and acknowledgment of all terms and conditions by Customer.

RECEIVED
 EMSL ANALYTICAL, INC.
 BELTSVILLE, MD
 NOV 30 4:53 PM



EMSL ANALYTICAL, INC.
LABORATORY PRODUCTS TRAINING

Microbiology Chain of Custody
EMSL Order Number (Lab Use Only):

182003848

EMSL ANALYTICAL, INC.
200 ROUTE 130 NORTH
CINNAMINSON, NJ 08077
PHONE: (800) 220-3675
FAX: (856) 786-0262

Additional pages of the chain of custody are only necessary if needed for additional sample information.

Sample #	Sample Location/Description	Sample Type	Potable/ NonPotable (Only for Waters)	Test Code	Volume/ Area	Date/Time Collected	Temperature (C) (Lab Use Only)
20-604-06	Room 33	Air	<input type="checkbox"/> P <input type="checkbox"/> NP	M001	75L	11/30 10:55	
20-604-07	Cafeteria	Air	<input type="checkbox"/> P <input type="checkbox"/> NP	M001	75L	11/30 11:04	
			<input type="checkbox"/> P <input type="checkbox"/> NP				
			<input type="checkbox"/> P <input type="checkbox"/> NP				
			<input type="checkbox"/> P <input type="checkbox"/> NP				
			<input type="checkbox"/> P <input type="checkbox"/> NP				
			<input type="checkbox"/> P <input type="checkbox"/> NP				
			<input type="checkbox"/> P <input type="checkbox"/> NP				
			<input type="checkbox"/> P <input type="checkbox"/> NP				
			<input type="checkbox"/> P <input type="checkbox"/> NP				
			<input type="checkbox"/> P <input type="checkbox"/> NP				
			<input type="checkbox"/> P <input type="checkbox"/> NP				
			<input type="checkbox"/> P <input type="checkbox"/> NP				
			<input type="checkbox"/> P <input type="checkbox"/> NP				
			<input type="checkbox"/> P <input type="checkbox"/> NP				
			<input type="checkbox"/> P <input type="checkbox"/> NP				
			<input type="checkbox"/> P <input type="checkbox"/> NP				
			<input type="checkbox"/> P <input type="checkbox"/> NP				
			<input type="checkbox"/> P <input type="checkbox"/> NP				
			<input type="checkbox"/> P <input type="checkbox"/> NP				
			<input type="checkbox"/> P <input type="checkbox"/> NP				
			<input type="checkbox"/> P <input type="checkbox"/> NP				
			<input type="checkbox"/> P <input type="checkbox"/> NP				
Comments/Special Instructions:							

EMSL Analytical, Inc.'s Laboratory Terms and Conditions are incorporated into this chain of custody by reference in their entirety. Submission of samples to EMSL Analytical, Inc. constitutes acceptance and acknowledgment of all terms and conditions by Customer.



EMSL Analytical, Inc.
Sample Transfer Form

Receiving Lab:	EMSL- BELTSVILLE	Phone Number:	3019375700
		Fax Number:	3019375701
Relinquished to:	EMSL- <i>Plymouth Mtg.</i>	Phone Number:	8002203675
		Fax Number:	8567860262

Does new lab hold equivalent or additional accreditation? * Yes No

EMSL Customer ID # (if known):	ATI125A
Client Name:	ATI INC
Client Project:	PGCPS - ARDMORE ES
Tests to be Performed:	M001
Date Received:	11/30/20
Date Relinquished:	12/2/20
Date Due:	1 WEEK - 12/7/20 @ 4:53 PM
Special Instructions: (e.g. Work Order # , required qualifications, project specific procedures/modifications)	

Relinquished by (Signature): <i>J. [Signature]</i>	Date: 12/2/20	Received by (Signature): <i>[Signature]</i>	Date: 12.3.20
Relinquished by (Signature):	Date:	Received by (Signature):	Date:

Customer Agreement- Please sign form and send to the receiving laboratory. By signing below, you agree to permit the above named receiving lab to transfer samples to a separate EMSL lab with equivalent qualifications* for analysis. The final report will be issued from the analyzing laboratory. Ensure any requirements are listed in special instructions.

Name (please print):	Signature:	Agent of:	Date:

If this is a recurring project or sample type that may require samples to be relinquished on a regular basis, a Standing Agreement form must be completed.

* Receiving and analyzing labs shall be aware of required qualifications of project prior to transfer of samples.
 Note: If customer has been notified and approved this transfer verbally or by e-mail, the receiving lab must sign for the customer above. EMSL employee filling out form on behalf of customer shall print name of person to whom they spoke, date agreement was received, and then sign under Signature.

Appendix B: Instrument Calibration Records

Certificate of Calibration

- () Buck™ BioAire Pump Calibration Rotameter
() Buck™ BioSlide Pump Calibration Rotameter

Serial number: R14536

Date Calibrated: 12/27/19

Calibration Due Date: 12/27/20

Flow Calibration

This is to certify that the rotameter listed above has been calibrated using a Buck Primary calibrator listed below which is calibrated according to A.P. Buck, Inc. calibration procedure APB-1, Ver. 6.2 and is traceable to the National Institute of Standards & Technology (N.I.S.T). A.P. Buck guarantees the accuracy of the rotameter to be within $\pm 5\%$ of the actual flow rate.

AMBIENT CONDITIONS: Temperature $74\pm 3^{\circ}$ F Relative Humidity $50\pm 10\%$

Description	MFR.	Model	Serial #
Primary Calibrator	A.P. Buck Inc.	M30B	<input type="checkbox"/> A40020 <input checked="" type="checkbox"/> A40021

QA Approval By: Maroni Menk

Information contained in this document should not be reproduced in any form without the written consent of A.P. Buck, Inc. It is for reference only and cannot be used as a form of endorsement by any private or governmental regulatory body.

A.P. BUCK, INC.
7101 Presidents Drive, Suite 110
Orlando, FL 32809
Phone: 407-851-8602
Fax: 407-851-8910

BUCK
A.P. BUCK, INC.



CERTIFICATE OF CALIBRATION AND TESTING

TSI Incorporated, 500 Cardigan Road, Shoreview, MN 55126 USA
Tel: 1-800-874-2811 1-651-490-2811 Fax: 1-651-490-3824 http://www.tsi.com

ENVIRONMENT CONDITIONS			MODEL	982
TEMPERATURE	74.0 (23.3)	°F (°C)	SERIAL NUMBER	P17100007
RELATIVE HUMIDITY	34	%RH		
BAROMETRIC PRESSURE	29.20 (988.8)	inHg (hPa)		

- AS LEFT IN TOLERANCE
 AS FOUND OUT OF TOLERANCE

- CALIBRATION VERIFICATION RESULTS -

SYSTEM G-101						Unit: ppm
GAS CO ₂ AS FOUND						ALLOWABLE RANGE
#	STANDARD	MEASURED	ALLOWABLE RANGE	#	STANDARD	MEASURED
1	0	0	0~50	4	3015.3	* 2902.7
2	499	458	449~549	5	5056	* 4859.6
3	1002	963	952~1052			

SYSTEM G-101						Unit: ppm
GAS CO AS FOUND						ALLOWABLE RANGE
#	STANDARD	MEASURED	ALLOWABLE RANGE	#	STANDARD	MEASURED
1	35.1	* 29.5	32.1~38.1	2	100.5	* 84.8

SYSTEM T-101						Unit: °F (°C)
TEMPERATURE AS FOUND						ALLOWABLE RANGE
#	STANDARD	MEASURED	ALLOWABLE RANGE	#	STANDARD	MEASURED
1	32.1 (0.0)	32.8 (0.4)	31.1~33.1 (-0.5~0.6)	2	140.02 (60.01)	* 141.31 (60.73)

SYSTEM H-102						Unit: %RH
HUMIDITY AS FOUND						ALLOWABLE RANGE
#	STANDARD	MEASURED	ALLOWABLE RANGE	#	STANDARD	MEASURED
1	10.0	10.4	7.0~13.0	4	70.0	67.1
2	30.0	29.3	27.0~33.0	5	90.01	* 85.88
3	50.0	48.5	47.0~53.0			

*Indicates Out-of-Tolerance Condition

TSI does hereby certify that the above described instrument conforms to the original manufacturer's specification (not applicable to As Found data) and has been calibrated using standards whose accuracies are traceable to the United States National Institute of Standards and Technology (NIST) or has been verified with respect to instrumentation whose accuracy is traceable to NIST, or is derived from accepted values of physical constants. TSI's calibration system is registered to ISO-9001:2015.

Measurement Variable	System ID	Last Cal.	Cal. Due	Measurement Variable	System ID	Last Cal.	Cal. Due
5000 CO ₂	14A044095	04-06-20	04-06-25	200 CO	149886	04-30-20	03-24-28
N ₂	T-0608	05-19-20	05-19-28	Air	T17939	04-09-20	04-09-28
Flow	E003341	09-03-19	09-30-20	Flow	E003980	04-22-20	04-30-21
Flow	E003525	01-06-20	01-31-21	Flow	E003342	09-03-19	09-30-20
2000 C4H8	EB0054467	08-13-19	08-12-22	100 C4H8	CC507339	03-24-20	03-24-28
Temperature	E010657	02-14-20	02-28-21	Temperature	E010658	02-14-20	02-28-21
Temperature	E010655	01-21-20	01-31-21	Humidity	E003539	02-26-20	08-31-20

Chimerica Inc.
 VERIFIED

June 15, 2020

DATE

Doc ID CERT_GEN_WCC



CERTIFICATE OF CALIBRATION AND TESTING

TSI Incorporated, 500 Cardigan Road, Shoreview, MN 55126 USA
Tel: 1-800-874-2811 1-651-490-2811 Fax: 1-651-490-3824 http://www.tsi.com

ENVIRONMENT CONDITIONS			MODEL	982
TEMPERATURE	70.41 (21.3)	°F (°C)	SERIAL NUMBER	P17100007
RELATIVE HUMIDITY	50.3	%RH		
BAROMETRIC PRESSURE	29.15 (987.1)	inHg (hPa)		

<input checked="" type="checkbox"/> AS LEFT	<input checked="" type="checkbox"/> IN TOLERANCE
<input type="checkbox"/> AS FOUND	<input type="checkbox"/> OUT OF TOLERANCE

- CALIBRATION VERIFICATION RESULTS -

TEMPERATURE VERIFICATION				SYSTEM T-101				Unit: °F (°C)
#	STANDARD	MEASURED	ALLOWABLE RANGE	#	STANDARD	MEASURED	ALLOWABLE RANGE	
1	22.1 (9.0)	31.9 (-0.1)	31.1-33.1 (-0.5-0.6)	2	140.0 (60.0)	140.5 (60.3)	139.0-141.0 (59.5-60.6)	

HUMIDITY VERIFICATION				SYSTEM H-102				Unit: %RH
#	STANDARD	MEASURED	ALLOWABLE RANGE	#	STANDARD	MEASURED	ALLOWABLE RANGE	
1	10.0	9.0	7.8-12.2	4	70.0	69.5	67.8-72.2	
2	30.0	29.1	27.8-32.2	5	90.0	88.7	87.8-92.2	
3	50.0	49.6	47.8-52.2					

CO2 GAS VERIFICATION				SYSTEM G-101				Unit: ppm
#	STANDARD	MEASURED	ALLOWABLE RANGE	#	STANDARD	MEASURED	ALLOWABLE RANGE	
1	0	0	0-50	4	3016	3012	2926-3107	
2	502	502	452-552	5	5056	5032	4904-5208	
3	1005	1019	955-1055					

CO GAS VERIFICATION				SYSTEM G-101				Unit: ppm
#	STANDARD	MEASURED	ALLOWABLE RANGE	#	STANDARD	MEASURED	ALLOWABLE RANGE	
1	35	36	32-38	2	101	100	98-104	

TSI does hereby certify that the above described instrument conforms to the original manufacturer's specification (not applicable to As Found data) and has been calibrated using standards whose accuracies are traceable to the United States National Institute of Standards and Technology (NIST) or has been verified with respect to instrumentation whose accuracy is traceable to NIST, or is derived from accepted values of physical constants. TSI's calibration system is registered to ISO-9001:2015.

Measurement Variable	System ID	Last Cal.	Cal. Due	Measurement Variable	System ID	Last Cal.	Cal. Due
Temperature	E010657	02-14-20	02-28-21	Temperature	E010658	02-14-20	02-28-21
Temperature	E010655	01-21-20	01-31-21	Humidity	E003539	02-26-20	08-31-20
5000 CO2	14A044095	04-06-20	04-06-25	200 CO	149886	04-30-20	03-24-28
N2	T-0608	05-19-20	05-19-28	Air	117939	04-09-20	04-09-28
Flow	E003341	09-03-19	09-30-20	Flow	E003980	04-22-20	04-30-21
Flow	E003525	01-06-20	01-31-21	Flow	E003342	09-03-19	09-30-20
2000 C4H8	EB0054467	08-13-19	08-12-22	100 C4H8	CC507339	03-24-20	03-24-28

ChaoVang

CALIBRATED

June 16, 2020

DATE

D:\CHD-CERT_GEN_WCC



CERTIFICATE OF CALIBRATION AND TESTING

TSI Incorporated, 500 Cardigan Road, Shoreview, MN 55126 USA
Tel: 1-800-874-2811 1-651-490-2811 Fax: 1-651-490-3824 http://www.tsi.com

ENVIRONMENT CONDITIONS			MODEL	7575-X
TEMPERATURE	70.72 (21.5)	°F (°C)	SERIAL NUMBER	7575X1711006
RELATIVE HUMIDITY	39.0	%RH		
BAROMETRIC PRESSURE	29.15 (987.1)	inHg (hPa)		

<input checked="" type="checkbox"/> AS LEFT	<input checked="" type="checkbox"/> IN TOLERANCE
<input type="checkbox"/> AS FOUND	<input type="checkbox"/> OUT OF TOLERANCE

- CALIBRATION VERIFICATION RESULTS -

THERMO COUPLE				SYSTEM PRESSURE01-02			Unit: °F (°C)
#	STANDARD	MEASURED	ALLOWABLE RANGE	#	STANDARD	MEASURED	ALLOWABLE RANGE
1	70.9 (21.6)	70.8 (21.6)	68.9-72.9 (20.5-22.7)				

BAROMETRIC PRESSURE				SYSTEM PRESSURE01-02			Unit: inHg (hPa)
#	STANDARD	MEASURED	ALLOWABLE RANGE	#	STANDARD	MEASURED	ALLOWABLE RANGE
1	29.22 (989.5)	29.23 (989.8)	28.64-29.80 (969.9-1009.1)				

TSI does hereby certify that the above described instrument conforms to the original manufacturer's specification (not applicable to As Found data) and has been calibrated using standards whose accuracies are traceable to the United States National Institute of Standards and Technology (NIST) or has been verified with respect to instrumentation whose accuracy is traceable to NIST, or is derived from accepted values of physical constants. TSI's calibration system is registered to ISO-9001:2015.

Measurement Variable	System ID	Last Cal.	Cal. Due	Measurement Variable	System ID	Last Cal.	Cal. Due
Temperature	E004626	02-14-20	02-28-21	Pressure	E005254	10-10-19	10-31-20
Pressure	E003982	01-24-20	07-31-20	DC Voltage	E003493	08-14-19	08-31-20

Chao Yang

June 15, 2020

CALIBRATED

DATE

Doc ID: CERT_GEN_WCC



CERTIFICATE OF CALIBRATION AND TESTING

TSI Incorporated, 500 Cardigan Road, Shoreview, MN 55126 USA
 Tel: 1-800-874-2811 1-651-490-2811 Fax: 1-651-490-3824 http://www.tsi.com

ENVIRONMENT CONDITIONS			MODEL	7575-X
TEMPERATURE	70.68 (21.5)	°F (°C)	SERIAL NUMBER	7575X1711006
RELATIVE HUMIDITY	38.0	%RH		
BAROMETRIC PRESSURE	29.16 (987.5)	inHg (hPa)		

- | | |
|--|--|
| <input type="checkbox"/> AS LEFT | <input checked="" type="checkbox"/> IN TOLERANCE |
| <input checked="" type="checkbox"/> AS FOUND | <input type="checkbox"/> OUT OF TOLERANCE |

- CALIBRATION VERIFICATION RESULTS -

THERMO COUPLE			SYSTEM PRESSURE01-02			Unit: °F (°C)	
#	STANDARD	MEASURED	ALLOWABLE RANGE	#	STANDARD	MEASURED	ALLOWABLE RANGE
1	70.8 (21.6)	71.1 (21.7)	68.8-72.8 (20.4-22.7)				

BAROMETRIC PRESSURE			SYSTEM PRESSURE01-02			Unit: inHg (hPa)	
#	STANDARD	MEASURED	ALLOWABLE RANGE	#	STANDARD	MEASURED	ALLOWABLE RANGE
1	29.22 (989.5)	29.17 (987.8)	28.64-29.80 (969.9-1009.1)				

TSI does hereby certify that the above described instrument conforms to the original manufacturer's specification (not applicable to As Found data) and has been calibrated using standards whose accuracies are traceable to the United States National Institute of Standards and Technology (NIST) or has been verified with respect to instrumentation whose accuracy is traceable to NIST, or is derived from accepted values of physical constants. TSI's calibration system is registered to ISO-9001:2015.

Measurement Variable	System ID	Last Cal.	Cal. Due	Measurement Variable	System ID	Last Cal.	Cal. Due
Temperature	E004626	02-14-20	02-28-21	Pressure	E005254	10-10-19	10-31-20
Pressure	E003982	01-24-20	07-31-20	DC Voltage	E003493	08-14-19	08-31-20

ChaoVang

 VERIFIED

June 15, 2020

 DATE

Doc. ID CERT_GEN_WCC