



Architecture | Engineering | Construction

9220 Rumsey Road, Suite 100, Columbia, MD 21045
T: 410.992.3424 | F: 410.992.1837

February 22, 2021

Prince George's County Public Schools
13300 Old Marlboro Pike
Upper Marlboro, Maryland 20772
Attention: Mr. Alex Baylor

RE: Indoor Air Quality Assessment, Mattaponi Elementary School
Purchase Order: 734977
ATI Project Number: 20-713

Dear Mr. Baylor:

Prince George's County Public Schools requested that ATI, Inc., conduct a proactive indoor air quality (IAQ) assessment at Mattaponi Elementary School on December 18, 2020 and a follow-up assessment on February 16, 2021. The assessments' findings are enclosed in the Executive Summary on page three, and the official laboratory reports for total fungal spore trap sampling are enclosed in Appendix A.

Thank you for the opportunity to provide Industrial Hygiene services for Prince George's County Public Schools. If you have any questions regarding this report, please contact us at (202) 643-4283.

Sincerely,
ATI, INC.

Reviewed By:

Mikal Frater
Industrial Hygienist

Nate Burgei, CIH, CSP
Certified Industrial Hygienist

Indoor Air Quality Assessment Report

Prince George's County Public Schools
Mattaponi Elementary School
11701 Duley Station Road
Upper Marlboro, MD 20772

Prepared for:

Prince George's County Public Schools
13300 Old Marlboro Pike
Upper Marlboro, Maryland 20772

February 22, 2021

Submitted by:



ATI Job # 20-713

Table of Contents

Table of Contents	1
1 Executive Summary	1
2 Assessment Methods	1
3 Visual Observations	2
4 Thermal Environmental Conditions for Human Occupancy	4
4.1 Temperature	4
4.2 Relative Humidity	5
4.3 Carbon Dioxide	5
4.4 Carbon Monoxide	6
5 Total Fungal Air Sampling Results	7
6 Summary of Findings	8

List of Tables

Table 1: Visual Observations and Sampling Locations	2
Table 2: Temperature	4
Table 3: Relative Humidity	5
Table 4: Carbon Dioxide	6
Table 5: Carbon Monoxide	7
Table 6: Aspergillus/Penicillium Concentration Comparison	8

Appendices

Appendix A: Laboratory Reports and Chain of Custody

Appendix B: Instrument Calibration Records

Abbreviations and Acronyms

AHU	Air-Handling Unit
AIHA	American Industrial Hygiene Association
ASHRAE	American Society of Heating, Refrigerating and Air-Conditioning Engineers
ASTM	American Society for Testing and Materials
CO	Carbon Monoxide
CO₂	Carbon Dioxide
EMLAP	Environmental Microbiology Laboratory Accreditation Program
HVAC	Heating, Ventilating, And Air-Conditioning
IAQ	Indoor Air Quality
NIST	National Institute for Standards and Technology
NVLAP	National Voluntary Laboratory Accreditation Program
RH	Relative Humidity
Rev.	Revision

Abbreviations involving scientific volume and measurements involving media or water sampling

Spores/m³	Mold spores per cubic meter of air
LPM	Liters Per Minute
NTE	Not to exceed
°F	degree Fahrenheit
PPM	Parts Per Million

1 Executive Summary

ATI conducted a proactive Indoor Air Quality (IAQ) assessment on December 18, 2020, at Mattaponi Elementary School, located at 11701 Duley Station Road, in Upper Marlboro, Maryland, and a follow-up assessment on February 16, 2021 in select rooms that had unusual fungal results in the initial inspection.

The initial assessment on December 18, 2020 included a visual assessment of randomly selected classrooms and other frequently occupied spaces, such as the cafeteria/gym, the main office, and randomly selected classrooms, for potential IAQ contributors and pathways. The Multipurpose Room, Room 3, Room 116, the Media Center, and Room 24 had unusual fungal spore concentrations during the initial assessment and were selected for a follow-up assessment on February 16, 2021 after actions were taken to reduce the presence of mold and repair any water issues discovered. As part of both assessments, ATI measured common IAQ comfort parameters, including temperature, relative humidity, carbon dioxide, and carbon monoxide. Also, ATI collected total fungal air samples on spore trap cassettes for microbiological analysis.

The following is a summary of the key findings from these assessments:

1. All tested locations on both assessments had temperatures within the ASHRAE recommended winter range of 68-75°F.
2. The relative humidity in all tested spaces from both assessments was less than the ASHRAE guidelines of <65%. Three tested locations on December 18, 2020 had a relative humidity less than 30%, which can cause occupant discomfort.
3. Carbon dioxide concentrations in all tested spaces during both assessments were less than the ASHRAE limit for carbon dioxide, relative to the outdoor carbon dioxide concentration on the day of each assessment.
4. Carbon monoxide concentrations were less than the IAQ meter's detection limit throughout the tested spaces for both assessments.
5. The *Aspergillus/Penicillium*-like spore concentrations in several of the tested spaces during the December 18, 2020 assessment were unusual and suggested significant indoor spore amplification.
6. The spaces with unusual spore concentrations were reassessed on February 16, 2021 and the *Aspergillus/Penicillium*-like spore concentrations were reduced up to 99.9%. The remaining measured *Aspergillus/Penicillium*-like spore concentrations are likely residual spores from before the remediation actions. ATI recommends an additional round of cleaning in Room 3 using HEPA vacuums and wet wiping of horizontal surfaces to remove residual spores. Also, the stained ceiling tile in Room 3 should be replaced.

2 Assessment Methods

Mikal Frater, IH of ATI, Inc. conducted the initial visual assessment and air sampling on December 18, 2020. Sampled rooms were randomly selected and accounted for approximately 10% of classrooms or a minimum of five samples. Ms. Frater documented visual observations at the time she collected the air samples. Nate Burgei, CIH, CSP conducted a follow-up inspection on February 16, 2021 in the Multipurpose Room, Media Center and Classrooms 3, 16 and 24, after the areas were treated for mold presence. ATI references the American Society of Heating, Refrigerating, and Air-Conditioning Engineers (ASHRAE) *Standard 62.1 – 2016* and *ASHRAE Standard 55 – 2017* when providing IAQ services to clients. ASHRAE is an industry leader on energy efficiency and indoor air quality.

All measurements and air samples were collected between three-six feet from floor elevation, which represents a typical adult breathing zone, and away from air-supply and return diffusers. Real-time direct readings for temperature, relative humidity, carbon dioxide (CO₂), and carbon monoxide (CO), were measured with a calibrated TSI Q-Trak 7575-X Meter and attached 982 Probe.

Total fungal air samples were collected with a Buck BioAire High-Volume Sampling Pump on Zefon Air-O-Cell spore-trap cassettes at a flow rate of 15 liters per minute for five minutes, for a sample volume of 75 liters. AMA Analytical Services, Inc. of Lanham, MD analyzed the samples using direct microscopic examination per ASTM D7391-09, which spores both viable and non-viable mold spores and particulates, which combined yields total fungal results. AMA participates in the National Institute of Standards and Technology’s (NIST) National Voluntary Laboratory Accreditation Program (NVLAP) for general laboratory performance and management, and the American Industrial Hygiene Association (AIHA) for Environmental Microbial Laboratory Accreditation Program (EMLAP). The AMA laboratory reports are included in Appendix A.

3 Visual Observations

Table 1 lists the areas, conditions, observations, and other pertinent details related to the initial and follow-up IAQ assessments. On both dates of sampling, few occupants were present in the school because of the COVID-19 global pandemic.

Table 1: Visual Observations and Sampling Locations

Sample Location	December 18, 2020 Observations
Outdoors – Parking Lot	<ul style="list-style-type: none"> • Cloudy skies, winds 3mph N • Light vehicle and foot traffic
Main Office	<ul style="list-style-type: none"> • Two occupants at time of assessment • Doors to corridor closed at time of assessment, doors to adjoining offices open • No odor, stained ceiling tiles, or visible growth observed • One air supplier in the form of a wall unit • Two radiators OFF at time of assessment • Space is approximately 432 ft.²
Multi-Purpose Room	<ul style="list-style-type: none"> • Cafeteria area • One occupant at time of assessment and door to corridor/kitchen was open • No signs of major water intrusion • Outdoor access via emergency exit • No stained ceiling tiles, observed odor or visible growth • Six air suppliers, four returns • Space is approximately 2,411 ft.²
Room 03	<ul style="list-style-type: none"> • One occupant at time of assessment, and door to corridor was open • One air supplier in the form of a wall unit, one A/C unit - off at time of sampling • No stained ceiling tiles, observed odor or visible growth • Peeling grid around ceiling tile • Space is approximately 1,013 ft.²
Room 16	<ul style="list-style-type: none"> • One air supplier in the form of a wall unit, cover grid removed at time of sampling • One A/C unit - off at time of sampling • Oscillating fan off at time of sampling, light dust accumulation • No significantly stained ceiling tiles, observed odor or visible growth • One occupant at time of assessment • Space is approximately 1,040 ft.²
Media Center	<ul style="list-style-type: none"> • Gazebo-like vaulted ceiling • No stained ceiling tiles, observed odor or visible growth • One occupant at time of assessment • Outdoor access via emergency exit • No visible mold

Sample Location	December 18, 2020 Observations
	<ul style="list-style-type: none"> Space is approximately 2,551 ft.²
Room 24	<ul style="list-style-type: none"> One occupant, and door to hallway was open at time of assessment No stained ceiling tiles, observed odor or visible growth Outdoor access via emergency exit One wall unit off at time of assessment, Dayton brand heater on during assessment, with light dust accumulation on return vent Four air suppliers, one air return Ceiling tiles and floors were clean Space is approximately 940 ft.²
Sample Location	February 16, 2021 Reassessment Observations
Multi-Purpose Room	<ul style="list-style-type: none"> One occupant in kitchen and doors to corridor/kitchen were open Outdoor access via emergency exit, door appeared well sealed No stained ceiling tiles, observed odor or visible growth Light dust/debris on floor, tables felt clean and free of dust There were books and supplies arranged on the stage Six air suppliers, four returns, and all appeared fairly clean
Room 03	<ul style="list-style-type: none"> No occupants at time of reassessment, door was open Heater and AC were not running, but the heater felt warm to touch There were books and supplies on every desk in the room Bathroom and classroom sink appeared clean, dry and free of leaks There was an empty/dry aquarium at the sink, contained gravel Signs of mild water stains on ceiling tile above electrical switch near sink Some cracking and bubbling paint around the windows, possible water damage Peeling grid around ceiling tile, and some ceiling tiles warped and peeling
Room 16	<ul style="list-style-type: none"> Door to hallway corridor open, and air was on Minor signs of water-stained ceiling tiles, possibly old, no signs of wetness No occupants at time of assessment Bathroom had signs of wetness around the base caulking of the toilet, water did not extend beyond the base; tiles were dry No signs of water leaks under or around the classroom sink
Media Center	<ul style="list-style-type: none"> Heat was on, doors to hallway corridor open Minor dust accumulation on floors, desks were mostly clear of dust Outdoor access via emergency exit, appeared well sealed Ceiling appeared free from major stains, no visible mold There were signs of water drips/streaks along painted beams, possibly old condensation stains or from cleanings
Room 24	<ul style="list-style-type: none"> No occupants, and door to hallway was open at time of assessment No stained ceiling tiles, observed odor or visible growth Outdoor access via emergency exit, door not fully sealed along doorhandle side One wall unit off at time of assessment, Dayton brand heater on during assessment, with light dust accumulation on return vent Four air suppliers, one air return Ceiling tiles and floors were clean, with minor dust accumulation, however floor tiles look warped and damaged, especially near the door and window

Sample Location	December 18, 2020 Observations
	<ul style="list-style-type: none"> Signs of prior water damage under classroom sink, mostly painted over with white paint; no signs of current water leaks
Outdoors	<ul style="list-style-type: none"> Overcast, light breeze and damp but not raining Parking lot was mostly empty with little to no foot traffic

4 Thermal Environmental Conditions for Human Occupancy

ASHRAE *Standard 55-2017, Thermal Environmental Conditions for Human Occupancy*, addresses thermal comfort in an office environment, which means that an employee wearing a normal amount of clothing feels neither too cold nor too warm. This standard discusses thermal comfort within the context of air temperature, humidity, and air movement and provides recommended ranges for temperature and humidity that are intended to satisfy 80% of occupants. The recommended ASHRAE ranges are referenced below by each comfort parameter.

4.1 Temperature

The ASHRAE standard establishes a winter comfort range of between 68°F and 75°F and a summer range of between 73°F and 79°F. The temperatures measured during the December 18, 2020 initial assessment and reassessment from February 16, 2021 are summarized in Table 2. As indicated by the data in the table, temperatures in the school on December 18, 2020 averaged between 68°F and 71°F, with all tested locations within the ASHRAE recommended winter range.

ATI reassessed select rooms that had unusual fungal spore concentrations on February 16, 2021, after remediation actions were completed. ATI also reassessed the temperature in the reassessed rooms. The average temperatures in the reassessed locations range from 68°F and 74°F, with all tested locations within the ASHRAE recommended winter range.

Table 2: Temperature

Sample Location	12/18/2020 Initial Assessment °F			ASHRAE Standard °F
	Min	Max	Average	
Outdoors	38	39	39	N/A
Indoors				
Main Office	67	68	68	68-75°F
Multi-Purpose Room	70	71	71	68-75°F
Room 03	70	70	70	68-75°F
Room 16	69	70	70	68-75°F
Media Center	69	69	69	68-75°F
Room 24	69	69	69	68-75°F
2/16/2021 Reassessment Temperature in °F				
Outdoors	49	49	49	N/A
Indoors				
Multi-Purpose Room	69	70	70	68-75°F
Room 03	74	74	74	68-75°F
Room 16	67	69	68	68-75°F
Media Center	70	71	71	68-75°F
Room 24	68	69	69	68-75°F

4.2 Relative Humidity

Relative humidity is a key factor for mold growth. Mold has the potential of growing on suitable surfaces with humidity levels above 65%. ASHRAE *Standard 62.1-2016, Ventilation for Acceptable Indoor Air Quality*, recommends a maximum indoor relative humidity of 65% to prevent condensation of moisture on surfaces. Relative humidity less than 30% may result in drying of occupants’ mucous membranes and skin. Relative humidity measurements for December 18, 2020 and February 16, 2021 are summarized in Table 3. As indicated by the data in the table, the average relative humidity ranged between 26% and 38% with all tested locations measuring less than the ASHRAE maximum recommendation of 65% relative humidity, and three of the tested locations also measuring less than 30% relative humidity.

ATI reassessed select rooms that had unusual fungal spore concentrations on February 16, 2021, after remediation actions were completed. ATI also reassessed the relative humidity in the space, and the average relative humidity ranged between 33% and 45% with all of the tested locations measuring less than the ASHRAE maximum recommendation of 65% relative humidity but greater than 30% relative humidity.

Table 3: Relative Humidity

Sample Location	12/18/2020 Initial Assessment (% RH)			ASHRAE Standard (% RH)
	Min	Max	Average	
Outdoors	27	30	29	N/A
Indoors				
Main Office	30	31	31	< 65
Multi-Purpose Room	28	29	29	< 65
Room 03	26	26	26	< 65
Room 16	37	38	38	< 65
Media Center	38	38	38	< 65
Room 24	25	28	27	< 65
2/16/2021 Reassessment Relative Humidity (%RH)				
Outdoors	50	57	54	N/A
Indoors				
Multi-Purpose Room	37	38	38	< 65
Room 03	34	34	34	< 65
Room 16	41	43	42	< 65
Media Center	44	46	45	< 65
Room 24	33	33	33	< 65

4.3 Carbon Dioxide

Carbon dioxide concentrations within an occupied building are a standard method used to gauge the efficiency of ventilation systems. Carbon dioxide is a by-product of human respiration and does not pose an acute health hazard alone. Elevated concentrations may suggest that insufficient fresh air is being supplied to an occupied space and/or that the ventilation system does not provide a sufficient rate of air exchange.

Research has indicated that buildings with adequately operating ventilation systems are able to remove odors generated by activities in an indoor office environment efficiently. ASHRAE *Standard 62.1-2016* states that comfort (odor) criteria with respect to human bioeffluents are likely to be satisfied if the ventilation can maintain indoor carbon dioxide concentrations

less than 700 parts per million (ppm) greater than the outdoor air concentration. Typically, outdoor carbon dioxide concentrations range from 300 ppm to 450 ppm, with the higher range typically found in urban areas during peak rush hour.

Carbon dioxide concentrations for December 18, 2020 are summarized in Table 4. On the day of the assessment, the average outdoor carbon dioxide concentration was 366 ppm, which calculates to a maximum indoor concentration of 1,066 ppm (700 + 366). All tested locations indoors were less than the recommended maximum for the day of the assessment.

ATI reassessed select rooms that had unusual fungal spore concentrations on February 16, 2021, after remediation actions were completed. The carbon dioxide concentrations measured during the reassessment are included in Table 4. The average outdoor carbon dioxide concentration on February 16, 2021 was 391 ppm, which calculates to a maximum indoor concentration of 1,091 ppm (700 + 391). All tested locations indoors were less than the recommended maximum for the day of the reassessment.

Table 4: Carbon Dioxide

Sample Location	12/18/2020 Initial Assessment Concentration (parts per million)			ASHRAE Standard (ppm) NTE
	Min	Max	Average	
Outdoors	364	368	366	N/A
Indoors				
Main Office	418	422	420	< 1,066
Multi-Purpose Room	384	387	386	< 1,066
Room 03	384	388	386	< 1,066
Room 16	394	395	395	< 1,066
Media Center	384	391	388	< 1,066
Room 24	389	389	389	< 1,066
2/16/2021 Reassessment Concentration (parts per million)				
Outdoors	389	392	391	N/A
Indoors				
Multi-Purpose Room	447	451	449	< 1,091
Room 03	450	452	451	< 1,091
Room 16	423	440	432	< 1,091
Media Center	431	440	436	< 1,091
Room 24	424	428	426	< 1,091

4.4 Carbon Monoxide

Carbon monoxide is a colorless and odorless gas produced by the incomplete combustion of carbon containing fuels. Oil, gasoline, diesel fuels, wood, coke, and coal are the major sources of carbon monoxide. ASHRAE recommends that carbon monoxide not exceed nine ppm indoors over an eight-hour time-weighted average. ATI measured carbon monoxide concentrations using a TSI Q-Trak model number 7575-X with an attached IAQ probe (model number 982). The instrument’s carbon monoxide sensor has an error range of ± 3% of the reading or three (3) ppm, whichever is greater. As indicated by the data in Table 5, carbon monoxide concentrations for December 18, 2020 were less than the Q-Trak’s detection limit throughout the school.

ATI reassessed select rooms that had unusual fungal spore concentrations on February 16, 2021 after remediation actions were completed. The carbon monoxide concentrations measured during the reassessment are included in Table 5. The carbon monoxide concentrations from the reassessment were also less than the Q-Trak’s limit of detection and less than the EPA/ASHRAE recommended maximum of 9 ppm.

Table 5: Carbon Monoxide

Sample Location	12/18/2020 Initial Assessment Concentration (parts per million)			ASHRAE Standard (ppm)
	Min	Max	Average	
Outdoors	<3	<3	<3	N/A
Indoors				
Main Office	<3	<3	<3	< 9
Multi-Purpose Room	<3	<3	<3	< 9
Room 03	<3	<3	<3	< 9
Room 16	<3	<3	<3	< 9
Media Center	<3	<3	<3	< 9
Room 24	<3	<3	<3	< 9
2/16/2021 Reassessment Concentration (parts per million)				
Outdoors	<3	<3	<3	N/A
Indoors				
Multi-Purpose Room	<3	<3	<3	< 9
Room 03	<3	<3	<3	< 9
Room 16	<3	<3	<3	< 9
Media Center	<3	<3	<3	< 9
Room 24	<3	<3	<3	< 9

5 Total Fungal Air Sampling Results

Mold is carried indoors through building entrances, open windows, loading docks, foot traffic into buildings, and the HVAC system. To thrive indoors, mold requires a food source, proper temperature and humidity to foster its growth.

The December 18, 2020 and February 16, 2021 mold assessments sampled air using spore trap cassettes in randomly selected classrooms and other areas throughout the facility. These cassettes collect both viable spores, those capable of producing more fungal colonies, and non-viable spores, which cannot reproduce. Based upon recognized industry practices, indoor mold concentrations are compared with those detected outdoors, which are also known as ambient or baseline samples.

In normal circumstances, the diversity of spores identified indoors and outdoors should be similar with some exceptions. The high concentration of one or two species of fungal spores identified indoors and the absence of the same species outdoors can indicate a moisture problem with the potential to degrade the air quality. Fungi species present indoors are typically found at levels ranging from approximately 10-50% of their levels in the outdoor air, reflecting the filtering by the building’s HVAC system.

The results from December 18, 2020 suggested unusual mold spore concentrations in five locations: The Multipurpose Room, Room 3, Room 116, Media Center, and Room 24. The total ambient, outdoor spore concentration was 416 spores/m³. Room 116 had the greatest total spore concentration of 570,492 spores/m³, with *Aspergillus/Penicillium*-like spores being the predominant spores present at 564,720 spores/m³. The *Cladosporium* concentration in Room 116 was 5,044 spores/m³, which was also greater than the outdoor concentration. The Multipurpose Room, Room 3, Media Center, and Room 24 had total spore concentrations of 1,404 spores/m³, 33,748 spores/m³, 3,484 spores/m³, and 163,124 spores/m³, respectively, with *Aspergillus/Penicillium*-like being the predominant spore type in each room with *Cladosporium* coming in second most prevalent.

The fungal spore concentrations in The Multipurpose Room and Media Center are just slightly greater than typical indoor mold concentrations of around 1,000 spores/m³ or less; however, the concentrations measured in those rooms do not suggest

significant mold growth and could be residual spores from prior growth, or possibly trivial amounts of mold growth normal in occupied spaces. The fungal spore concentrations in Rooms 3 and 24 are greater than the typical occupied space, and suggest a significant level of mold amplification indoors. ATI recommended evaluating these tested spaces and the surrounding areas to try and identify water sources, abate any mold issues and clean the area before retesting the space.

The Multipurpose Room, Media Center and Classrooms 3, 16 and 24 were reassessed for airborne fungal spore concentrations on February 16, 2021 after the initial assessment indicated the unusual presence of airborne mold spores. The reassessment results were promising in all locations, indicating a reduction in spore concentrations by 97% - 99% in the rooms with the greatest spore concentrations. The *Cladosporium* concentrations in all sampled locations were 106 spores/m³ or less, and the *Aspergillus/Penicillium*-like spore concentrations ranged from 424 spores/m³ to 1,113 spores/m³. While the *Aspergillus/Penicillium*-like concentrations in all reassessed locations were greater than the outdoor concentrations, it is possible the spores measured could be residual spores left in the areas from before the treatment and clean-up activities.

Differences in concentrations between both dates of assessment are summarized in Table 6.

ATI recommends an additional cleaning round using HEPA vacuums on the floors and walls throughout Classroom 3 and wet wiping down all horizontal surfaces to remove residual spores. Ensure any water intrusion sources have been identified and remediated. The ceiling tiles in the hallway of Classroom 3 showed signs of possible water damage and should be replaced. Ensure HVAC filters are replaced per the recommended intervals.

Table 6: *Aspergillus/Penicillium* Concentration Comparison

Sample Location	December 18, 2020 Concentrations	February 16, 2021 Concentrations	% Change
Multi-purpose Room	1,404	583	-58%
Room 3	32,500	1,113	-97%
Room 16	564,720	795	-99%
Media Center	2,652	424	-84%
Room 24	162,240	901	-99%

The official laboratory reports with spore trap samples collected on December 18, 2020 and February 16, 2021 are presented in Appendix A.

6 Summary of Findings

1. All tested locations on both assessments had temperatures within the ASHRAE recommended winter range of 68-75°F.
2. The relative humidity in all tested spaces from both assessments was less than the ASHRAE guidelines of <65%. Three tested locations on December 18, 2020 had a relative humidity less than 30%, which can cause occupant discomfort.
3. Carbon dioxide concentrations in all tested spaces during both assessments were less than the ASHRAE limit for carbon dioxide, relative to the outdoor carbon dioxide concentration on the day of each assessment.
4. Carbon monoxide concentrations were less than the IAQ meter’s detection limit throughout the tested spaces for both assessments.
5. The *Aspergillus/Penicillium*-like spore concentrations in several of the tested spaces during the December 18, 2020 assessment were unusual and suggested significant indoor spore amplification.

- 6. The spaces with unusual spore concentrations were reassessed on February 16, 2021 and the *Aspergillus/Penicillium*-like spore concentrations were reduced up to 99.9%. The remaining measured *Aspergillus/Penicillium*-like spore concentrations are likely residual spores from before the remediation actions. ATI recommends an additional round of cleaning in Room 3 using HEPA vacuums and wet wiping of horizontal surfaces to remove residual spores. Also, the stained ceiling tile in Room 3 should be replaced.

We appreciate the opportunity to provide these IAQ testing services for you. If you have any questions, please contact us at (202) 643-4283.

Best,
ATI, INC.

Reviewed By:



Mikal Frater
Industrial Hygienist



Nate Burgei, CIH, CSP
Certified Industrial Hygienist

Appendix A: Laboratory Report and Chain of Custody

CERTIFICATE OF ANALYSIS

ASTM D7391-09 Spore Trap Analysis Report

Chain of Custody: 285311
Client: ATI, Inc.
Address: 9220 Rumsey Road
 Suite 100
 Columbia, MD 21045
Attention: Mikal Frater

Job Name: IAQ-PGCPS
Job Location: Mattaponi Elementary
Job Number: 20-713
P.O. Number: Not Provided

Date Submitted: 12/18/2020
Person Submitting: Mikal Frater
Date Analyzed: 12/28/2020
Report Date: 12/28/2020

AMA Sample # 285311-1
Client ID 20-713-1
Analyst ID TLW
Collection Apparatus Air-O-Cell
Sample Volume (L) 75
Sample Condition Acceptable
Debris Loading 2
Location Parking Lot

AMA Sample # 285311-2
Client ID 20-713-2
Analyst ID TLW
Collection Apparatus Air-O-Cell
Sample Volume (L) 0
Sample Condition Acceptable
Debris Loading 1
Location Field Blank

AMA Sample # 285311-3
Client ID 20-713-3
Analyst ID TLW
Collection Apparatus Air-O-Cell
Sample Volume (L) 75
Sample Condition Acceptable
Debris Loading 2
Location Main Office

	Raw Ct	Trav/Flds	A.S.	sp/m ³	%		Raw Ct	Trav/Flds	A.S.	sp/m ³	%		Raw Ct	Trav/Flds	A.S.	sp/m ³	%	
Alternaria						Alternaria						Alternaria						
Ascospores	3	15	52	156	37.5%	Ascospores						Ascospores	4	15	52	208	26.7%	
Basidiospores	2	15	52	104	25%	Basidiospores						Basidiospores	5	15	52	260	33.3%	
Bipolaris/Drechslera/Helm.						Bipolaris/Drechslera/Helm.						Bipolaris/Drechslera/Helm.						
Chaetomium						Chaetomium						Chaetomium						
Cladosporium	1	15	52	52	12.5%	Cladosporium						Cladosporium	1	15	52	52	6.7%	
Curvularia						Curvularia						Curvularia						
Penicillium / Aspergillus	2	15	52	104	25%	Penicillium / Aspergillus						Penicillium / Aspergillus	1	15	52	52	6.7%	
Smuts/Periconia/Myxomycetes						Smuts/Periconia/Myxomycetes						Smuts/Periconia/Myxomycetes	1	15	52	52	6.7%	
Stachybotrys/Memnoniella						Stachybotrys/Memnoniella						Stachybotrys/Memnoniella						
Ulocladium						Ulocladium						Ulocladium						
Unknown						Unknown						Unknown	1	15	52	52	6.7%	
Other Colorless						Other Colorless						Other Colorless	2	15	52	104	13.3%	
Epicoccum						Epicoccum						Epicoccum						
Pithomyces						Pithomyces						Pithomyces						
Hyphal Fragments*						Hyphal Fragments*						Hyphal Fragments*						
Total Raw Ct:	8					Total Raw Ct:	0					Total Raw Ct:	15					
				Total sp/m³:	416					Total sp/m³:	0					Total sp/m³:	780	

Comments

Comments

Comments

No mold spores observed.

CERTIFICATE OF ANALYSIS

ASTM D7391-09 Spore Trap Analysis Report

Chain of Custody: 285311
Client: ATI, Inc.
Address: 9220 Rumsey Road
Suite 100
Columbia, MD 21045
Attention: Mikal Frater

Job Name: IAQ-PGCPs
Job Location: Mattaponi Elementary
Job Number: 20-713
P.O. Number: Not Provided

Date Submitted: 12/18/2020
Person Submitting: Mikal Frater
Date Analyzed: 12/28/2020
Report Date: 12/28/2020

AMA Sample # 285311-4
Client ID 20-713-4
Analyst ID TLW
Collection Apparatus Air-O-Cell
Sample Volume (L) 75
Sample Condition Acceptable
Debris Loading 2
Location Multi-purpose Room

AMA Sample # 285311-5
Client ID 20-713-5
Analyst ID TLW
Collection Apparatus Air-O-Cell
Sample Volume (L) 75
Sample Condition Acceptable
Debris Loading 2
Location Room 3

AMA Sample # 285311-6
Client ID 20-713-6
Analyst ID TLW
Collection Apparatus Air-O-Cell
Sample Volume (L) 75
Sample Condition Acceptable
Debris Loading 2
Location Room 116

	Raw Ct	Trav/Flds	A.S.	sp/m ³	%		Raw Ct	Trav/Flds	A.S.	sp/m ³	%		Raw Ct	Trav/Flds	A.S.	sp/m ³	%
Alternaria						Alternaria						Alternaria	1	15	52	52	0.1%
Ascospores						Ascospores						Ascospores	2	15	52	104	0.2%
Basidiospores						Basidiospores	10	15	52	520	6.7%	Basidiospores	8	15	52	416	1%
Bipolaris/Drechslera/Helm.						Bipolaris/Drechslera/Helm.						Bipolaris/Drechslera/Helm.					
Chaetomium						Chaetomium						Chaetomium					
Cladosporium	Present	15	52	<52		Cladosporium	13	15	52	676	8.7%	Cladosporium	97	15	52	5044	11.6%
Curvularia						Curvularia						Curvularia					
Penicillium / Aspergillus	27	15	52	1404	100%	Penicillium / Aspergillus	125	3	260	32500	83.9%	Penicillium / Aspergillus	724	1	780	564720	86.7%
Smuts/Periconia/Myxomycetes						Smuts/Periconia/Myxomycetes						Smuts/Periconia/Myxomycetes	2	15	52	104	0.2%
Stachybotrys/Memnoniella						Stachybotrys/Memnoniella						Stachybotrys/Memnoniella					
Ulocladium						Ulocladium						Ulocladium					
Unknown						Unknown						Unknown					
Other Colorless						Other Colorless						Other Colorless					
Epicoccum						Epicoccum	1	15	52	52	0.7%	Epicoccum	1	15	52	52	0.1%
Pithomyces						Pithomyces						Pithomyces					
Hyphal Fragments*						Hyphal Fragments*	1	15	52	52	0.7%	Hyphal Fragments*	3	15	52	156	0.4%
Total Raw Ct:	27			Total sp/m³:	1404	Total Raw Ct:	149			Total sp/m³:	33748	Total Raw Ct:	835			Total sp/m³:	570492
Comments						Comments						Comments					

CERTIFICATE OF ANALYSIS

ASTM D7391-09 Spore Trap Analysis Report

Chain of Custody: 285311
Client: ATI, Inc.
Address: 9220 Rumsey Road
 Suite 100
 Columbia, MD 21045
Attention: Mikal Frater

Job Name: IAQ-PGCPS
Job Location: Mattaponi Elementary
Job Number: 20-713
P.O. Number: Not Provided

Date Submitted: 12/18/2020
Person Submitting: Mikal Frater
Date Analyzed: 12/28/2020
Report Date: 12/28/2020

AMA Sample # 285311-7
Client ID 20-713-7
Analyst ID TLW
Collection Apparatus Air-O-Cell
Sample Volume (L) 75
Sample Condition Acceptable
Debris Loading 1
Location Media Center

AMA Sample # 285311-8
Client ID 20-713-8
Analyst ID TLW
Collection Apparatus Air-O-Cell
Sample Volume (L) 75
Sample Condition Acceptable
Debris Loading 1
Location Room 24

	Raw Ct	Trav/Flds	A.S.	sp/m ³	%
Alternaria					
Ascospores	2	15	52	104	3%
Basidiospores	4	15	52	208	6%
Bipolaris/Drechslera/Helm.	Present	15	52	<52	
Chaetomium					
Cladosporium	10	15	52	520	14.9%
Curvularia					
Penicillium / Aspergillus	51	15	52	2652	76.1%
Smuts/Periconia/Myxomycetes	Present	15	52	<52	
Stachybotrys/Memnoniella					
Ulocladium					
Unknown					
Other Colorless					
Epicoccum					
Pithomyces					
Hyphal Fragments*	1	15	52	52	1.5%
Total Raw Ct:	67		Total sp/m³:	3484	

Comments

	Raw Ct	Trav/Flds	A.S.	sp/m ³	%
Alternaria					
Ascospores	1	15	52	52	0.4%
Basidiospores	7	15	52	364	3.1%
Bipolaris/Drechslera/Helm.					
Chaetomium					
Cladosporium	7	15	52	364	3.1%
Curvularia					
Penicillium / Aspergillus	208	1	780	162240	92.4%
Smuts/Periconia/Myxomycetes	1	15	52	52	0.4%
Stachybotrys/Memnoniella					
Ulocladium					
Unknown					
Other Colorless					
Epicoccum					
Pithomyces	1	15	52	52	0.4%
Hyphal Fragments*	3	15	52	156	1.3%
Total Raw Ct:	225		Total sp/m³:	163124	

Comments

CERTIFICATE OF ANALYSIS

ASTM D7391-09 Spore Trap Analysis Report

Chain of Custody: 285311
Client: ATI, Inc.
Address: 9220 Rumsey Road
 Suite 100
 Columbia, MD 21045
Attention: Mikal Frater

Job Name: IAQ-PGOPS
Job Location: Mattaponi Elementary
Job Number: 20-713
P.O. Number: Not Provided

Date Submitted: 12/18/2020
Person Submitting: Mikal Frater
Date Analyzed: 12/28/2020
Report Date: 12/28/2020

Spore Comparison Guide

The criteria for these specifications are outlined, but not limited to those listed, below. Final specifications may differ from the listed criteria for certain samples. AMA Analytical Services, Inc. reserves the right to make changes to these criteria at any time without notice.



Stachybotrys / Memnoniella, and Chaetomium	Other Spores* (Control Present)	Other Spores* (No Control)
1-4 Spores: Yellow 5-9 Spores: Orange 10+ Spores: Red	< 10 Spores: Insignificant (no color) <= Control's spore count: Green Between Control and 2x Control: Yellow Between 2x Control and 3x Control: Orange 3x+ Control: Red	< 10 Spores: Insignificant (no color) 10-20 Spores: Yellow 20-50 Spores: Orange 50+ Spores: Red

*No evaluation is provided for the following spore types: Other, Other Colorless, and Unknown Fungi, and Misc

Interpretation of the data contained in this report is the sole responsibility of the client or the persons who conducted the field work. There are no federal or national standards for the number of fungal spores that may be present in the indoor environment. As a general rule and guideline that is widely accepted in the indoor air quality field, the numbers and types of spores that are present in the indoor environment should be comparable to those that are present outdoors at any given time. There will always be some mold spores present in "Normal" indoor environments. The purpose of sampling and counting spores is to help determine whether an abnormal condition exists within the indoor environment and if it does, to help pinpoint the area of contamination. Spore counts should not be used as the sole determining factor of mold contamination. There are many factors that can cause anomalies in the comparison of indoor and outdoor samples due to the dynamic nature of both of those environments.

This report is provided for informational and comparative purposes only and should not be relied upon for any other purpose. Sampling techniques, possible contaminants, unrepresentative samples and other similar or dissimilar factors may affect these results. With the statistical evaluation provided, as with all statistical comparisons and analyses, false-positive and false-negative results can and do occur. AMA Analytical Services, Inc. hereby disclaims any liability for any and all direct, indirect, punitive, incidental, special or consequential damages arising out of the use or interpretation of the data contained in, or any actions taken or omitted in reliance upon, this report.

CERTIFICATE OF ANALYSIS

ASTM D7391-09 Spore Trap Analysis Report

Chain of Custody: 285311
Client: ATI, Inc.
Address: 9220 Rumsey Road
Suite 100
Columbia, MD 21045
Attention: Mikal Frater

Job Name: IAQ-PGCPs
Job Location: Mattaponi Elementary
Job Number: 20-713
P.O. Number: Not Provided

Date Submitted: 12/18/2020
Person Submitting: Mikal Frater
Date Analyzed: 12/28/2020
Report Date: 12/28/2020

General Comments, Disclaimers, and Footnotes

Analytical Method: Sample are analyzed following the instructions and guidelines outlined in ASTM 7391-09.

Sample Condition: Acceptable: The sample was collected and delivered to the our location without disturbing the material on the sampling media.
Unacceptable: 1. The sample trace (TR) has been disturbed. 2. The sample was damaged or otherwise unsuitable for analysis.
0 = No particulate matter detected; 1 = >nd-~5% Particulate Loading; 2 = ~5%-25% Particulate Loading; 3 = ~25%- 75% Particulate Loading; 4 = ~75%-90% Particulate Loading; 5 = >90% Particulate Loading

Spore Notes: Based on their small size and very few distinguishing characteristics, Aspergillus and Penicillium cannot be differentiated by non-viable sampling methods. There are other types of spores whose morphology is similar to Aspergillus and Penicillium and cannot be differentiated by non-viable sampling methods. Examples of these similar spores are Acremonium, Paecilomyces, Wallemia, Trichoderma, Scopulariopsis, and Gliocladium.
Smuts, Periconia and Myxomycetes are three different types of genera that have similar morphological characteristics.
Bipolaris/Dreschlera/Helm: Bipolaris / Dreschlera / Helminthosporium are three different types of genera that have smiliar morphological characteristics.
Other Colorless represents all colorless spores that are non-distinctive and unidentifiable.
*Hyphal Fragments: A portion of the mycelium that becomes separated from the remainder of the thallus (vegetative body), each of which has the capacity to grow and form new individuals. Results for hyphal fragments are in fragments/m3 and are not incorporated in the total spore concentration.
The droplet symbol (💧) refers to water-intrusion indicator spores. These fungal spores, when found on indoor air samples, can be an indication of moisture sources and resultant fungal growth that may be problematic.

Quantification: Analytical Sensitivity (A.S.): This is dependent on the volume of air collected, size of the trace, ocular diameter, and the amount of the trace that was analyzed.
The value of "Present" indicated in the Raw Count column represents the presence of this spore type during the preliminary exam at 400x. The Raw Count converts to a whole number if the spore type is encountered again during the 600x-1,000x enumeration. The sp/m3 concentration will be reported as less than the analytical sensitivity if "Present" is reported in the Raw Count.
Results are reported to 3 significant figures. sp/m3: Spores per cubic meter.
Uncertainty: for raw count in the range of 0-50 the SR is 0.375, 51-100 SR=0.333, 101-200 SR=0.257, >200 SR=0.245
All results are to be considered preliminary and subject to change unless signed by the Technical Director or Deputy.
Analyst(s): Tristan Ward



Technical Director Tristan Ward

This report applies only to the sample, or samples, investigated and is not necessarily indicative of the quality or condition of apparently identical or similar products. As a mutual protection to clients, the public, and these Laboratories, this report is submitted and accepted for the exclusive use of the client to whom it is addressed and upon the condition that it is not to be used, in whole or in part, in any advertising or publicity matter without prior written authorization from us. Sample types, locations, and collection protocols are based upon the information provided by the persons submitting them and, unless collected by personnel of these Laboratories, we expressly disclaim any knowledge and liability for the accuracy and completeness of this information. Residual sample material will be discarded in accordance with the appropriate regulatory guidelines, unless otherwise requested by the client.

MOLD SPORE DESCRIPTIONS

Alternaria

Alternaria is ubiquitous in the environment and are normal agents of decay and decomposition. The spores are airborne and common outdoors than indoors isolated from plants, soil, and food. Indoors, the spores are found in house dust, carpets, textiles, wallboard and window frames. The production of melanin-like pigment is one of its major identifying characteristics. The club-shaped spores (conidia) are single or in long chains. They can grow thick colonies with grayish-white surfaces at the beginning which later darken to greenish black or olive brown colors. Health Effects: Allergies are common, but serious infections are rare, except in people with compromised immune systems. Certain species of this genus are often prolific producers of a variety of toxic compounds whose effects on human health are not well known.

Ascospores

Ascospores are spores formed inside an ascus (asci-plural) or sac-like cell which is contained inside a fruiting body called an ascocarp or an ascoma (ascomata-plural). An ascus typically contains a definite number of ascospores, usually eight. Ascospores are unique in shape, size, and color as to the Genus/species they represent. These spores are specific to fungi classified as Ascomycetes. They are ubiquitous in nature. Many decay organic matter, others are plant or animal pathogens. They can grow indoors on damp materials. Release of ascospores are released by forcible ejection and dispersed by wind, water, animals and other agents. Health Effects: Depending on the Genera, Ascospores may be allergenic.

Basidiospores

Basidiospores are reproductive spores produced by a group of fungi called basidiomycetes. This group includes the mushrooms, shelf fungi and various other macrofungi. Basidiospores serve as the main air (wind) dispersal units for the fungi and their release is dependent upon moisture. The structure of the spore complex can develop in various manners resulting in different appearances. It is often found growing in soil, decaying plant debris, compost piles and fruit rot. Indoors, it can be found on water damaged building materials (chipboard /OSB, plywood, wallpaper, and glue) as well as on food items (dried foods, cheeses, fruits, herbs, spices, cereals). Health effects: Some basidiospores may produce toxins and can act as allergens. They have not been reported to be pathogens.

Bip/Drech/Helminth

Bipolaris, Drechslera, and Helminthosporium are found on grasses, grains, various plants, and decaying food. They tend to grow in semi-dry environments and some species can be found indoors. Because of their microscopic similarities, these three genera are grouped together on both viable and non-viable analysis. Microscopically, the spores are cylindrical, fusiform, or club-shaped with protrusions, Health Effects: Can cause hay fever and asthma, allergic fungal sinusitis, and pathogenic sinusitis.

Cladosporium

Cladosporium is the most common indoor and outdoor mold. The spores are wind dispersed and are often extremely abundant in outdoor air. Many species are commonly found on living and dead plant material. Indoors, they may grow on surfaces with high moisture or high humidity levels such as damp window sills, poorly ventilated bathrooms and soiled refrigerators. It produces powdery or velvety olive-green to brown or black colonies. The conidia (spores) vary depending on the species and are formed in simple or branching chains with multi-attachment points. Health Effects: Cladosporium species are rarely pathogenic to humans, but have been reported to occasionally cause sinusitis and pulmonary infections as well as infections of the skin and toenails. The airborne spores are significant allergens, and in large amounts they may severely affect asthmatics and people with respiratory diseases.

Epicoccum

Epicoccum is a cosmopolitan fungus that is often found growing outside in soil, plant litter, decaying plants, and damaged plant tissue. Indoors, it can be found growing on a variety of building materials including paper and textiles. Colonies have a rapid growth rate with cottony texture, initially yellow or orange becoming brown to black in color. Conidiophores or fruiting bodies produce dense masses where conidia (spores) arise. Spores are round to pear-shaped, smooth to warty, brown to black in color and muriform (partitioned in both directions, like a soccer ball). Health Effects: This mold can act as a potential allergen. Some people may experience hay fever and or asthma. This mold has not been linked to any human or animal infection.

Hyphal Fragments

Hyphal Fragments are segments or pieces of hyphae or mycelium that may have broken off during sampling (air, tape, dust). The mycelium is the entire mass of hyphae that makes up the vegetative body of a fungus. The presence of hyphal fragments may indicate the presence of viable mold.

Other Colorless

- "Other Colorless" are all non-distinctive, unidentifiable, colorless spores seen on spore trap samples and include all the genera that do not have distinguishing morphology to belong to any of the other defined categories."

Penicillium/Aspergillus Like

Penicillium and Aspergillus are ubiquitous, filamentous fungi that are found in soil, decaying plant debris, compost piles, and in the air. Indoors, spores are commonly found in house dust, in water-damaged buildings (wallpaper, wallpaper glue, decaying fabrics, moist chipboards, and behind paint) as well as fruit and grains. They are the most common fungal genera, worldwide. Both produce chains of spores that are small, round to oval, colorless or slightly pigmented, and smooth to rough walled. These spores are indistinguishable between the two as well as other genera, such as Gliocladium, Trichoderma, Paecilomyces, and Scopulariopsis. They differ as to their conidiophores or fruiting bodies. While, Aspergillus spores are produced from phialides supported on conidia heads or swollen vesicles, Penicillium spores are produced on finger-like projections. Depending on species, typical colonies of Aspergillus are initially white and later turn to either shades of green, yellow, orange, brown or black. Texture is usually velvety to cottony. Typical colonies of Penicillium, other than Penicillium marneffeii (yeast-like at 37oC), grow rapidly, white in color at first, later becoming bluish green with white borders with velvety to powdery textures depending on species. Some species produce radial patterns. Health Effects: Both Aspergillus and Penicillium are potential allergens. Several species of Aspergillus (*A. flavus* and *A. parasiticus*) produce aflatoxins or naturally occurring mycotoxins that are toxic and carcinogenic. These are found in contaminated foodstuff and are hazardous to consumers. Penicillium has only one known species that is pathogenic to humans (*P. marneffeii*) that causes lethal systemic infection (Penicilliosis) in immunocompromised individuals.

Pithomyces

Pithomyces is a cosmopolitan, dark-walled fungus often found growing outside in soil, decaying leaves, and grasses. It is rarely found growing indoors, but will grow on paper given the right conditions. Colonies grow rapidly, cottony in texture with light to dark brownish black surface color. Spores are single, oval yellow to dark brown, multi-celled, and usually rough. One identification feature of the spores is the resemblance to barrels. Another identifying character is beak-like structures on young spores. Spores of *Pithomyces chartarum* are most common and are identified by distinctive transverse septa. This species has been linked to facial eczema in sheep. Health Effects: It is a potential but not well-studied allergen or human pathogen.

Smuts/Periconia/Myxomycetes

Smuts, Periconia, and Myxomycetes spores are grouped together due to their similar round, brown morphology. Smuts are outdoor parasitic plant pathogens. They rarely grow indoors but may grow on host plants if appropriate conditions are present. They are parasitic plant pathogens. They can be found on cereal crops, grasses, flowering plants, weed, and other fungi. They can cause allergies. Periconia are found in soils, dead herbaceous stems and leaf spots, and grasses. They have wind dispersed dry spores. Their spores are abundant in the air but it is not known if they are allergenic. Myxomycetes are found on decaying logs, stumps and dead leaves. They have wind-dispersed dry spores and wet motile (amoebic phase) spores. During favorable conditions they move about like amoebae. They form dry airborne spores when conditions are unfavorable. They are rarely found indoors. Health Effects: They may cause Type 1 allergies (hay fever, asthma). No human infections have been reported.

Unknown Fungi

"Unknown Fungi" are spores that cannot be identified under direct microscopic analysis. This includes partial spores. This category also includes spores that are hidden or hard to see during microscopic examination due to heavy presence of particulate.



AMA Analytical Services, Inc.

Focused on Results www.amalab.com
 AIHA-LAP (#100470) NVLAP (#101143-0) NY ELAP (10920)
 4475 Forbes Blvd. • Lanham, MD 20706
 (301) 459-2640 • (800) 346-0961 • Fax (301) 459-2643

CHAIN OF CUSTODY

(Please Refer To This
 Number For Inquires)

285311

Mailing/Billing Information:

1. Client Name: ATI, Inc.
 2. Address 1: 4221 Forbes Blvd
 3. Address 2: Suite 250
 4. Address 3: Lanham, MD 20706
 5. Phone #: _____ Fax #: _____

Submittal Information:

1. Job Name: IAQ - PCCPS
 2. Job Location: Mattaponi Elementary
 3. Job #: 20-713 P.O. #: _____
 4. Contact Person: Mikal Frater Cell: (818) 702-8621
 5. Collected by: " Cell: _____

Reporting Info (Results provided as soon as technically feasible). If no TAT/Reporting Info is provided, AMA will assign defaults of 5-Day and email/fax to contacts on file.

AFTER HOURS (must be pre-scheduled) <input type="checkbox"/> 4 Hours <input type="checkbox"/> Immediate Date Due: _____ <input type="checkbox"/> 24 Hours Time Due: _____ Comments: _____		NORMAL BUSINESS HOURS <input type="checkbox"/> 4 Hours <input type="checkbox"/> Same Day <input type="checkbox"/> Next Day <input type="checkbox"/> 2 Day <input type="checkbox"/> 3 Day <input checked="" type="checkbox"/> 5 Day + Date Due: <u>12/28/20</u> <input type="checkbox"/> Results Required By Noon		REPORT TO: <input checked="" type="checkbox"/> Email: <u>mikal@atiinc.com</u> <input type="checkbox"/> Email 2: _____ <input type="checkbox"/> Verbals: _____
--------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------	--	-------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------	--	-------------------------------------------------------------------------------------------------------------------------------------------------------------------------------

Asbestos Analysis

*PCM Air - Please Indicate Filter Type: _____

- NIOSH 7400 _____ (QTY)
- Fiberglass _____ (QTY)

TEM Air* - Please Indicate Filter Type: _____

- AHERA _____ (QTY)
- NIOSH 7402 _____ (QTY)
- Other (specify _____) _____ (QTY)

PLM Bulk

- EPA 600 - Visual Estimate _____ (QTY) Pos Stop
- EPA Point Count _____ (QTY)
- NY State Friable 198.1 _____ (QTY)
- Grav. Reduction ELAP 198.6 _____ (QTY)
- Other (specify _____) _____ (QTY)

MISC

- Vermiculite
 - Asbestos Soil PLM__ (Qual) PLM__ (Quan) PLM/TEM__ (Qual) PLM/TEM__ (Quan)
- *It is recommended that blank samples be submitted with all air and surface samples.

TEM Bulk

- ELAP 198.4/Chatfield _____ (QTY)
- NY State PLM/TEM _____ (QTY)
- Residual Ash _____ (QTY)

TEM Dust*

- Qual. (pres/abs) Vacuum/Dust _____ (QTY)
- Quan. (s/area) Vacuum D5755-95 _____ (QTY)
- Quan. (s/area) Dust D6480-99 _____ (QTY)

TEM Water

- Qual. (pres/abs) _____ (QTY)
- ELAP 198.2/EPA 100.2 _____ (QTY)
- EPA 100.1 _____ (QTY)

All samples received in good condition unless otherwise noted.
 (TEM Water samples _____ °C)

Metals Analysis

- Pb Paint Chip _____ (QTY)
- *Pb Dust Wipe (wipe type _____) _____ (QTY)
- *Pb Air _____ (QTY)
- Pb Soil/Solid _____ (QTY)
- Pb TCLP _____ (QTY)
- Drinking Water Pb _____ (QTY) Cu _____ (QTY) As _____ (QTY)
- Waste Water Pb _____ (QTY) Cu _____ (QTY) As _____ (QTY)
- Pb Furnace (Media _____) _____ (QTY)

Fungal Analysis

- Collection Apparatus for Spore Traps/Air Samples: _____
 Collection Media _____
- *Spore-Trap 8 _____ (QTY) Surface Vacuum Dust _____ (QTY)
 - *Surface Swab _____ (QTY) Culturable ID Genus (Media _____) _____ (QTY)
 - *Surface Tape _____ (QTY) Culturable ID Species (Media _____) _____ (QTY)
 - Other (Specify _____) _____ (QTY)

CLIENT ID #	SAMPLE INFORMATION		DATE/TIME	VOL (L)/Wipe Area	ANALYSIS							MATRIX					CLIENT CONTACT		
	SAMPLE LOCATION/ID				TEM	PCM	PLM	LEAD	MOLD	AIR	BULK	DUST	WATER AND OTHER	SPORE TRAP	TAPE	SWAB	(LABORATORY STAFF ONLY)		
20-713	1	Parking Lot	12/18/20 11:35	75L														Date/Time:	Contact:By:
20-713	2	Field Blank																	
20-713	3	Main office	11:50																
20-713	4	MultiPurpose Rm	11:58																
20-713	5	Room 3	12:06															Date/Time:	Contact:By:
20-713	6	Room 16	12:14																
20-713	7	Medin Center	12:21																
20-713	8	Room 24	12:28															Date/Time:	Contact:By:

Relinquished by:	Print Name <u>Mikal Frater</u>	Signature <u>Mikal Frater</u>	Date <u>12/18/20</u>	Time <u>1:30 PM</u>	Shipping Information <input type="checkbox"/> UPS <input checked="" type="checkbox"/> In-Person <input type="checkbox"/> Other <input type="checkbox"/> FedEx <input type="checkbox"/> Drop Box <input type="checkbox"/> USPS <input type="checkbox"/> Courier Airbill/Tracking No: _____
Received by:					
Relinquished by:					
Received for Lab by:			<u>12/18/20</u>	<u>1:30</u>	

CERTIFICATE OF ANALYSIS

ASTM D7391-09 Spore Trap Analysis Report

Chain of Custody: 324882
Client: ATI, Inc.
Address: 9220 Rumsey Road
Suite 100
Columbia, MD 21045
Attention: Nate Burgei

Job Name: Mattaponi Elementary
Job Location: Not Provided
Job Number: 20-713
P.O. Number: Not Provided

Date Submitted: 02/16/2021
Person Submitting: Nate Burgei
Date Analyzed: 02/17/2021
Report Date: 02/17/2021

AMA Sample # 324882-1
Client ID 31638840
Analyst ID MG
Collection Apparatus Air-O-Cell
Sample Volume (L) 75
Sample Condition Acceptable
Debris Loading 1
Location Multipurpose Room

AMA Sample # 324882-2
Client ID 31638844
Analyst ID MG
Collection Apparatus Air-O-Cell
Sample Volume (L) 75
Sample Condition Acceptable
Debris Loading 1
Location Classroom 3

AMA Sample # 324882-3
Client ID 31638812
Analyst ID MG
Collection Apparatus Air-O-Cell
Sample Volume (L) 75
Sample Condition Acceptable
Debris Loading 1
Location Media Center

	Raw Ct	Trav/Flds	A.S.	sp/m ³	%
Alternaria					
Ascospores	2	15	53	106	11.1%
Basidiospores	4	15	53	212	22.2%
Bipolaris/Drechslera/Helm.					
Chaetomium					
Cladosporium	1	15	53	53	5.6%
Curvularia					
Penicillium / Aspergillus	11	15	53	583	61.1%
Smuts/Periconia/Myxomycetes					
Stachybotrys/Memnoniella					
Ulocladium					
Unknown					
Hyphal Fragments*					
Total Raw Ct:	18			Total sp/m³:	954

Comments

	Raw Ct	Trav/Flds	A.S.	sp/m ³	%
Alternaria					
Ascospores	4	15	53	212	12.5%
Basidiospores	5	15	53	265	15.6%
Bipolaris/Drechslera/Helm.					
Chaetomium					
Cladosporium	2	15	53	106	6.3%
Curvularia					
Penicillium / Aspergillus	21	15	53	1113	65.6%
Smuts/Periconia/Myxomycetes					
Stachybotrys/Memnoniella					
Ulocladium					
Unknown					
Hyphal Fragments*	1	15	53	53	3.1%
Total Raw Ct:	32			Total sp/m³:	1696

Comments

	Raw Ct	Trav/Flds	A.S.	sp/m ³	%
Alternaria					
Ascospores	10	15	53	530	50%
Basidiospores	2	15	53	106	10%
Bipolaris/Drechslera/Helm.					
Chaetomium					
Cladosporium					
Curvularia					
Penicillium / Aspergillus	8	15	53	424	40%
Smuts/Periconia/Myxomycetes					
Stachybotrys/Memnoniella					
Ulocladium					
Unknown					
Hyphal Fragments*					
Total Raw Ct:	20			Total sp/m³:	1060

Comments



CERTIFICATE OF ANALYSIS

ASTM D7391-09 Spore Trap Analysis Report

Chain of Custody: 324882
Client: ATI, Inc.
Address: 9220 Rumsey Road
Suite 100
Columbia, MD 21045
Attention: Nate Burgei

Job Name: Mattaponi Elementary
Job Location: Not Provided
Job Number: 20-713
P.O. Number: Not Provided

Date Submitted: 02/16/2021
Person Submitting: Nate Burgei
Date Analyzed: 02/17/2021
Report Date: 02/17/2021

AMA Sample # 324882-4
Client ID 31638799
Analyst ID MG
Collection Apparatus Air-O-Cell
Sample Volume (L) 75
Sample Condition Acceptable
Debris Loading 1
Location Room 24

AMA Sample # 324882-5
Client ID 31561516
Analyst ID MG
Collection Apparatus Air-O-Cell
Sample Volume (L) 75
Sample Condition Acceptable
Debris Loading 1
Location Room 16

AMA Sample # 324882-6
Client ID 31561391
Analyst ID MG
Collection Apparatus Air-O-Cell
Sample Volume (L) 75
Sample Condition Acceptable
Debris Loading 1
Location Outdoors

	Raw Ct	Trav/Flds	A.S.	sp/m ³	%
Alternaria					
Ascospores	9	15	53	477	28.1%
Basidiospores	5	15	53	265	15.6%
Bipolaris/Drechslera/Helm.					
Chaetomium					
Cladosporium	1	15	53	53	3.1%
Curvularia					
Penicillium / Aspergillus	17	15	53	901	53.1%
Smuts/Periconia/Myxomycetes					
Stachybotrys/Memnoniella					
Ulocladium					
Unknown					
Total Raw Ct:	32			Total sp/m³:	1696

Comments

	Raw Ct	Trav/Flds	A.S.	sp/m ³	%
Alternaria					
Ascospores	19	15	53	1007	42.2%
Basidiospores	11	15	53	583	24.4%
Bipolaris/Drechslera/Helm.					
Chaetomium					
Cladosporium					
Curvularia					
Penicillium / Aspergillus	15	15	53	795	33.3%
Smuts/Periconia/Myxomycetes					
Stachybotrys/Memnoniella					
Ulocladium					
Unknown					
Total Raw Ct:	45			Total sp/m³:	2385

Comments

	Raw Ct	Trav/Flds	A.S.	sp/m ³	%
Alternaria					
Ascospores	114	14	56	6384	64%
Basidiospores	60	15	53	3180	33.7%
Bipolaris/Drechslera/Helm.					
Chaetomium					
Cladosporium					
Curvularia					
Penicillium / Aspergillus	4	15	53	212	2.2%
Smuts/Periconia/Myxomycetes					
Stachybotrys/Memnoniella					
Ulocladium					
Unknown					
Total Raw Ct:	178			Total sp/m³:	9776

Comments

CERTIFICATE OF ANALYSIS

ASTM D7391-09 Spore Trap Analysis Report

Chain of Custody: 324882
Client: ATI, Inc.
Address: 9220 Rumsey Road
 Suite 100
 Columbia, MD 21045
Attention: Nate Burgei

Job Name: Mattaponi Elementary
Job Location: Not Provided
Job Number: 20-713
P.O. Number: Not Provided

Date Submitted: 02/16/2021
Person Submitting: Nate Burgei
Date Analyzed: 02/17/2021
Report Date: 02/17/2021

Spore Comparison Guide

The criteria for these specifications are outlined, but not limited to those listed, below. Final specifications may differ from the listed criteria for certain samples. AMA Analytical Services, Inc. reserves the right to make changes to these criteria at any time without notice.



Stachybotrys / Memnoniella, and Chaetomium	Other Spores* (Control Present)	Other Spores* (No Control)
1-4 Spores: Yellow 5-9 Spores: Orange 10+ Spores: Red	< 10 Spores: Insignificant (no color) <= Control's spore count: Green Between Control and 2x Control: Yellow Between 2x Control and 3x Control: Orange 3x+ Control: Red	< 10 Spores: Insignificant (no color) 10-20 Spores: Yellow 20-50 Spores: Orange 50+ Spores: Red

*No evaluation is provided for the following spore types: Other, Other Colorless, and Unknown Fungi, and Misc

Interpretation of the data contained in this report is the sole responsibility of the client or the persons who conducted the field work. There are no federal or national standards for the number of fungal spores that may be present in the indoor environment. As a general rule and guideline that is widely accepted in the indoor air quality field, the numbers and types of spores that are present in the indoor environment should be comparable to those that are present outdoors at any given time. There will always be some mold spores present in "Normal" indoor environments. The purpose of sampling and counting spores is to help determine whether an abnormal condition exists within the indoor environment and if it does, to help pinpoint the area of contamination. Spore counts should not be used as the sole determining factor of mold contamination. There are many factors that can cause anomalies in the comparison of indoor and outdoor samples due to the dynamic nature of both of those environments.

This report is provided for informational and comparative purposes only and should not be relied upon for any other purpose. Sampling techniques, possible contaminants, unrepresentative samples and other similar or dissimilar factors may affect these results. With the statistical evaluation provided, as with all statistical comparisons and analyses, false-positive and false-negative results can and do occur. AMA Analytical Services, Inc. hereby disclaims any liability for any and all direct, indirect, punitive, incidental, special or consequential damages arising out of the use or interpretation of the data contained in, or any actions taken or omitted in reliance upon, this report.

CERTIFICATE OF ANALYSIS

ASTM D7391-09 Spore Trap Analysis Report

Chain of Custody: 324882
Client: ATI, Inc.
Address: 9220 Rumsey Road
Suite 100
Columbia, MD 21045
Attention: Nate Burgei

Job Name: Mattaponi Elementary
Job Location: Not Provided
Job Number: 20-713
P.O. Number: Not Provided

Date Submitted: 02/16/2021
Person Submitting: Nate Burgei
Date Analyzed: 02/17/2021
Report Date: 02/17/2021

General Comments, Disclaimers, and Footnotes

Analytical Method: Sample are analyzed following the instructions and guidelines outlined in ASTM 7391-09.

Sample Condition: Acceptable: The sample was collected and delivered to the our location without disturbing the material on the sampling media.
Unacceptable: 1. The sample trace (TR) has been disturbed. 2. The sample was damaged or otherwise unsuitable for analysis.
0 = No particulate matter detected; 1 = >nd-~5% Particulate Loading; 2 = ~5%-25% Particulate Loading; 3 = ~25%- 75% Particulate Loading; 4 = ~75%-90% Particulate Loading; 5 = >90% Particulate Loading

Spore Notes: Based on their small size and very few distinguishing characteristics, Aspergillus and Penicillium cannot be differentiated by non-viable sampling methods. There are other types of spores whose morphology is similar to Aspergillus and Penicillium and cannot be differentiated by non-viable sampling methods. Examples of these similar spores are Acremonium, Paecilomyces, Wallemia, Trichoderma, Scopulariopsis, and Gliocladium.
Smuts, Periconia and Myxomycetes are three different types of genera that have similar morphological characteristics.
Bipolaris/Dreschlera/Helm: Bipolaris / Dreschlera / Helminthosporium are three different types of genera that have smiliar morphological characteristics.
Other Colorless represents all colorless spores that are non-distinctive and unidentifiable.
*Hyphal Fragments: A portion of the mycelium that becomes separated from the remainder of the thallus (vegetative body), each of which has the capacity to grow and form new individuals. Results for hyphal fragments are in fragments/m3 and are not incorporated in the total spore concentration.
The droplet symbol (💧) refers to water-intrusion indicator spores. These fungal spores, when found on indoor air samples, can be an indication of moisture sources and resultant fungal growth that may be problematic.

Quantification: Analytical Sensitivity (A.S.): This is dependent on the volume of air collected, size of the trace, ocular diameter, and the amount of the trace that was analyzed.
The value of "Present" indicated in the Raw Count column represents the presence of this spore type during the preliminary exam at 400x. The Raw Count converts to a whole number if the spore type is encountered again during the 600x-1,000x enumeration. The sp/m3 concentration will be reported as less than the analytical sensitivity if "Present" is reported in the Raw Count.
Results are reported to 3 significant figures. sp/m3: Spores per cubic meter.
Uncertainty: for raw count in the range of 0-50 the SR is 0.375, 51-100 SR=0.333, 101-200 SR=0.257, >200 SR=0.245
All results are to be considered preliminary and subject to change unless signed by the Technical Director or Deputy.
Analyst(s): Michael Greenberg



Technical Director Tristan Ward

This report applies only to the sample, or samples, investigated and is not necessarily indicative of the quality or condition of apparently identical or similar products. As a mutual protection to clients, the public, and these Laboratories, this report is submitted and accepted for the exclusive use of the client to whom it is addressed and upon the condition that it is not to be used, in whole or in part, in any advertising or publicity matter without prior written authorization from us. Sample types, locations, and collection protocols are based upon the information provided by the persons submitting them and, unless collected by personnel of these Laboratories, we expressly disclaim any knowledge and liability for the accuracy and completeness of this information. Residual sample material will be discarded in accordance with the appropriate regulatory guidelines, unless otherwise requested by the client.

MOLD SPORE DESCRIPTIONS

Ascospores

Ascospores are spores formed inside an ascus (asci-plural) or sac-like cell which is contained inside a fruiting body called an ascocarp or an ascoma (ascomata-plural). An ascus typically contains a definite number of ascospores, usually eight. Ascospores are unique in shape, size, and color as to the Genus/species they represent. These spores are specific to fungi classified as Ascomycetes. They are ubiquitous in nature. Many decay organic matter, others are plant or animal pathogens. They can grow indoors on damp materials. Release of ascospores are released by forcible ejection and dispersed by wind, water, animals and other agents. Health Effects: Depending on the Genera, Ascospores may be allergenic.

Basidiospores

Basidiospores are reproductive spores produced by a group of fungi called basidiomycetes. This group includes the mushrooms, shelf fungi and various other macrofungi. Basidiospores serve as the main air (wind) dispersal units for the fungi and their release is dependent upon moisture. The structure of the spore complex can develop in various manners resulting in different appearances. It is often found growing in soil, decaying plant debris, compost piles and fruit rot. Indoors, it can be found on water damaged building materials (chipboard /OSB, plywood, wallpaper, and glue) as well as on food items (dried foods, cheeses, fruits, herbs, spices, cereals). Health effects: Some basidiospores may produce toxins and can act as allergens. They have not been reported to be pathogens.

Cladosporium

Cladosporium is the most common indoor and outdoor mold. The spores are wind dispersed and are often extremely abundant in outdoor air. Many species are commonly found on living and dead plant material. Indoors, they may grow on surfaces with high moisture or high humidity levels such as damp window sills, poorly ventilated bathrooms and soiled refrigerators. It produces powdery or velvety olive-green to brown or black colonies. The conidia (spores) vary depending on the species and are formed in simple or branching chains with multi-attachment points. Health Effects: Cladosporium species are rarely pathogenic to humans, but have been reported to occasionally cause sinusitis and pulmonary infections as well as infections of the skin and toenails. The airborne spores are significant allergens, and in large amounts they may severely affect asthmatics and people with respiratory diseases.

Hyphal Fragments

Hyphal Fragments are segments or pieces of hyphae or mycelium that may have broken off during sampling (air, tape, dust). The mycelium is the entire mass of hyphae that makes up the vegetative body of a fungus. The presence of hyphal fragments may indicate the presence of viable mold.

Penicillium/Aspergillus Like

Penicillium and Aspergillus are ubiquitous, filamentous fungi that are found in soil, decaying plant debris, compost piles, and in the air. Indoors, spores are commonly found in house dust, in water-damaged buildings (wallpaper, wallpaper glue, decaying fabrics, moist chipboards, and behind paint) as well as fruit and grains. They are the most common fungal genera, worldwide. Both produce chains of spores that are small, round to oval, colorless or slightly pigmented, and smooth to rough walled. These spores are indistinguishable between the two as well as other genera, such as Gliocladium, Trichoderma, Paecilomyces, and Scopulariopsis. They differ as to their conidiophores or fruiting bodies. While, Aspergillus spores are produced from phialides supported on conidia heads or swollen vesicles, Penicillium spores are produced on finger-like projections. Depending on species, typical colonies of Aspergillus are initially white and later turn to either shades of green, yellow, orange, brown or black. Texture is usually velvety to cottony. Typical colonies of Penicillium, other than Penicillium marneffeii (yeast-like at 37oC), grow rapidly, white in color at first, later becoming bluish green with white borders with velvety to powdery textures depending on species. Some species produce radial patterns. Health Effects: Both Aspergillus and Penicillium are potential allergens. Several species of Aspergillus (A. flavus and A. parasiticus) produce aflatoxins or naturally occurring mycotoxins that are toxic and carcinogenic. These are found in contaminated foodstuff and are hazardous to consumers. Penicillium has only one known species that is pathogenic to humans (P. marneffeii) that causes lethal systemic infection (Penicilliosis) in immunocompromised individuals.



AMA Analytical Services, Inc.

Focused on Results www.amalab.com
 AIHA-LAP (#100470) NVLAP (#101143-0) NY ELAP (10920)
 4475 Forbes Blvd. • Lanham, MD 20706
 (301) 459-2640 • (800) 346-0961 • Fax (301) 459-2643

(Please Refer To This
 Number For Inquires)

324882

CHAIN OF CUSTODY

Mailing/Billing Information:

1. Client Name: ATI, inc.
2. Address 1: 4221 FORBES BLVD STE 250
3. Address 2: LANHAM MD 20706
4. Address 3: _____
5. Phone #: _____ Fax #: _____

Submittal Information:

1. Job Name: MATTAPONI ELEMENTARY
2. Job Location: _____
3. Job #: 20-713 P.O. #: _____
4. Contact Person: Nate Burgei Cell: _____
5. Collected by: Nate Burgei Cell: 014-286-5919

Reporting Info (Results provided as soon as technically feasible). If no TAT/Reporting Info is provided, AMA will assign defaults of 5-Day and email to contacts on file.

AFTER HOURS (must be pre-scheduled) <input type="checkbox"/> 4 Hours <input type="checkbox"/> Late Night <input type="checkbox"/> Immediate Date Due: _____ <input type="checkbox"/> 24 Hours Time Due: _____ Comments: _____		NORMAL BUSINESS HOURS <input type="checkbox"/> 4 Hours <input type="checkbox"/> 3 Day <input type="checkbox"/> Same Day <input type="checkbox"/> 5 Day + <input checked="" type="checkbox"/> Next Day <input type="checkbox"/> Results Required By Noon <input type="checkbox"/> 2 Day Date Due: <u>2/17/21</u> (Additional fee may apply)		REPORT TO: <input type="checkbox"/> Email: <u>nate.burgei@atiinc.com</u> <input type="checkbox"/> Email 2: <u>courtney@atiinc.com</u> <input type="checkbox"/> Verbal: _____
--------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------	--	------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------	--	----------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------

Asbestos Analysis

*PCM Air – Please Indicate Filter Type: _____

- NIOSH 7400 (QTY)
- Fiberglass (QTY)

TEM Air* – Please Indicate Filter Type: _____

- AHERA (QTY)
- NIOSH 7402 (QTY)
- Other (specify _____) (QTY)

PLM Bulk

- EPA 600 – Visual Estimate (QTY) Pos Stop
- EPA Point Count (QTY)
- NY State Friable 198.1 (QTY)
- Grav. Reduction ELAP 198.6 (QTY)
- Other (specify _____) (QTY)

MISC

- Asbestos Soil ASTM D7521 PLM (Qual) PLM (Quan) PLM/TEM (Qual)
- PLM/TEM (Quan)

*It is recommended that blank samples be submitted with all air and surface samples

TEM Bulk

- ELAP 198.4/Chatfield (QTY)
- NY State PLM/TEM (QTY)
- Residual Ash (QTY)
- Vermiculite (QTY)

TEM Dust*

- Qual. (pres/abs) Vacuum/Dust (QTY)
- Quan. (s/area) Vacuum D5755-95 (QTY)
- Quan. (s/area) Dust D6480-99 (QTY)

TEM Water

- Qual. (pres/abs) (QTY)
- ELAP 198.2/EPA 100.2 (QTY)
- EPA 100.1 (QTY)

All samples received in good condition unless otherwise noted.

Lab use only (TEM Water samples _____ °C)

If field data sheets are submitted, there is no need to complete bottom section.

Metals Analysis

- Pb Paint Chip % by Weight (QTY) mg/cm² (QTY)
- *Pb Dust Wipe (wipe type _____) (QTY)
- *Pb Air (QTY)
- Pb Soil/Solid (QTY)
- Pb TCLP (QTY)
- Drinking Water Pb (QTY) Cu (QTY)
- Waste Water Pb (QTY) Cu (QTY)
- Pb Furnace (Media _____) (QTY)

Fungal Analysis

- Collection Apparatus for Spore Traps/Air Samples: 7
- Collection Media Air-o-cell
- *Spore-Trap 7 (QTY) Surface Vacuum Dust (QTY)
- *Surface Swab (QTY)
- *Surface Tape (QTY)
- Other (Specify _____) (QTY)

CLIENT ID #	SAMPLE INFORMATION SAMPLE LOCATION/ID	DATE/ TIME	VOL (L)/ Wipe Area	ANALYSIS							MATRIX						COMMENTS / SPECIAL INSTRUCTIONS
				TEM	PCM	PLM	LEAD	MOLD	AIR	BULK	DUST	WATER AND OTHER	SPORE TRAP	TAPE	SWAB		
31638840	MULTIPURPOSE ROOM	2/16 9:19a	75L											X			
31638844	Classroom 3	2/16 9:29	75L											X			
31638812	MEDIA CENTER	2/16 9:42	75L											X			
31638899	ROOM 24	2/16 9:51	75L											X			31638799
31561516	ROOM 16	2/16 10:01	75L											X			
31561391	OUTDOORS	2/16 10:13	75L											X			
31637239			OL											X			
	<i>Received but not listed (KMAX)</i>																

Relinquished by: <u>Nate Burgei</u>	Signature:	Date: <u>2/16/21</u>	Time: <u>11:43</u>	Shipping Information <input type="checkbox"/> UPS <input type="checkbox"/> In-Person <input type="checkbox"/> Other <input type="checkbox"/> FedEx <input checked="" type="checkbox"/> Drop Box <input type="checkbox"/> USPS <input type="checkbox"/> Courier
Received by:		Date: <u>2/16/21</u>	Time: <u>11:45</u>	

Appendix B: Instrument Calibration Records

Certificate of Calibration

(✓) Buck™ BioAire Pump Calibration Rotameter

() Buck™ BioSlide Pump Calibration Rotameter

Serial number: R15046

Date Calibrated: 11/12/2020

Calibration Due Date: 11/12/2021

Flow Calibration

This is to certify that the rotameter listed above has been calibrated using a Buck Primary calibrator listed below which is calibrated according to A.P. Buck, Inc. calibration procedure APB-1, Ver. 6.2 and is traceable to the National Institute of Standards & Technology (N.I.S.T). A.P. Buck guarantees the accuracy of the rotameter to be within $\pm 5\%$ of the actual flow rate.

AMBIENT CONDITIONS: Temperature $74 \pm 3^{\circ}$ F Relative Humidity $50 \pm 10\%$

Description	MFR.	Model	Serial #
Primary Calibrator	A.P. Buck Inc.	M30B	<input type="checkbox"/> A40020 <input checked="" type="checkbox"/> A40021

QA Approval By: *Moreni Munk*

Information contained in this document should not be reproduced in any form without the written consent of A.P. Buck, Inc. It is for reference only and cannot be used as a form of endorsement by any private or governmental regulatory body.

A.P. BUCK, INC.
7101 Presidents Drive, Suite 110
Orlando, FL 32809
Phone: 407-851-8602
Fax: 407-851-8910





CERTIFICATE OF CALIBRATION AND TESTING

TSI Incorporated, 500 Cardigan Road, Shoreview, MN 55126 USA
Tel: 1-800-874-2811 1-651-490-2811 Fax: 1-651-490-3824 http://www.tsi.com

ENVIRONMENT CONDITIONS			MODEL	7575-X
TEMPERATURE	70.72 (21.5)	°F (°C)	SERIAL NUMBER	7575X1711006
RELATIVE HUMIDITY	39.0	%RH		
BAROMETRIC PRESSURE	29.15 (987.1)	inHg (hPa)		

<input checked="" type="checkbox"/> AS LEFT	<input checked="" type="checkbox"/> IN TOLERANCE
<input type="checkbox"/> AS FOUND	<input type="checkbox"/> OUT OF TOLERANCE

- CALIBRATION VERIFICATION RESULTS -

THERMO COUPLE				SYSTEM PRESSURE01-02			Unit: °F (°C)
#	STANDARD	MEASURED	ALLOWABLE RANGE	#	STANDARD	MEASURED	ALLOWABLE RANGE
1	70.9 (21.6)	70.8 (21.6)	68.9-72.9 (20.5-22.7)				

BAROMETRIC PRESSURE				SYSTEM PRESSURE01-02			Unit: inHg (hPa)
#	STANDARD	MEASURED	ALLOWABLE RANGE	#	STANDARD	MEASURED	ALLOWABLE RANGE
1	29.22 (989.5)	29.23 (989.8)	28.64-29.80 (969.9-1009.1)				

TSI does hereby certify that the above described instrument conforms to the original manufacturer's specification (not applicable to As Found data) and has been calibrated using standards whose accuracies are traceable to the United States National Institute of Standards and Technology (NIST) or has been verified with respect to instrumentation whose accuracy is traceable to NIST, or is derived from accepted values of physical constants. TSI's calibration system is registered to ISO-9001:2015.

Measurement Variable	System ID	Last Cal.	Cal. Due	Measurement Variable	System ID	Last Cal.	Cal. Due
Temperature	E004626	02-14-20	02-28-21	Pressure	E005254	10-10-19	10-31-20
Pressure	E003982	01-24-20	07-31-20	DC Voltage	E003493	08-14-19	08-31-20

Chao Yang

June 15, 2020

CALIBRATED

DATE

Doc ID: CERT_GEN_WCC



CERTIFICATE OF CALIBRATION AND TESTING

TSI Incorporated, 500 Cardigan Road, Shoreview, MN 55126 USA
 Tel: 1-800-874-2811 1-651-490-2811 Fax: 1-651-490-3824 http://www.tsi.com

ENVIRONMENT CONDITIONS			MODEL	7575-X
TEMPERATURE	70.68 (21.5)	°F (°C)	SERIAL NUMBER	7575X1711006
RELATIVE HUMIDITY	38.0	%RH		
BAROMETRIC PRESSURE	29.16 (987.5)	inHg (hPa)		

AS LEFT IN TOLERANCE
 AS FOUND OUT OF TOLERANCE

- CALIBRATION VERIFICATION RESULTS -

THERMO COUPLE		SYSTEM PRESSURE01-02				Unit: °F (°C)	
#	STANDARD	MEASURED	ALLOWABLE RANGE	#	STANDARD	MEASURED	ALLOWABLE RANGE
1	70.8 (21.6)	71.1 (21.7)	68.8-72.8 (20.4-22.7)				

BAROMETRIC PRESSURE		SYSTEM PRESSURE01-02				Unit: inHg (hPa)	
#	STANDARD	MEASURED	ALLOWABLE RANGE	#	STANDARD	MEASURED	ALLOWABLE RANGE
1	29.22 (989.5)	29.17 (987.8)	28.64-29.80 (969.9-1009.1)				

TSI does hereby certify that the above described instrument conforms to the original manufacturer's specification (not applicable to As Found data) and has been calibrated using standards whose accuracies are traceable to the United States National Institute of Standards and Technology (NIST) or has been verified with respect to instrumentation whose accuracy is traceable to NIST, or is derived from accepted values of physical constants. TSI's calibration system is registered to ISO-9001:2015.

Measurement Variable	System ID	Last Cal.	Cal. Due	Measurement Variable	System ID	Last Cal.	Cal. Due
Temperature	E004626	02-14-20	02-28-21	Pressure	E005254	10-10-19	10-31-20
Pressure	E003982	01-24-20	07-31-20	DC Voltage	E003493	08-14-19	08-31-20

ChaoVang

VERIFIED

June 15, 2020

DATE

Doc. ID CERT_GEN_WCC



CERTIFICATE OF CALIBRATION AND TESTING

TSI Incorporated, 500 Cardigan Road, Shoreview, MN 55126 USA
Tel: 1-800-874-2811 1-651-490-2811 Fax: 1-651-490-3824 http://www.tsi.com

ENVIRONMENT CONDITIONS			MODEL	982
TEMPERATURE	74.0 (23.3)	°F (°C)	SERIAL NUMBER	P17100007
RELATIVE HUMIDITY	34	%RH		
BAROMETRIC PRESSURE	29.20 (988.8)	inHg (hPa)		

AS LEFT IN TOLERANCE
 AS FOUND OUT OF TOLERANCE

- CALIBRATION VERIFICATION RESULTS -

GAS CO ₂ AS FOUND				SYSTEM G-101			Unit: ppm
#	STANDARD	MEASURED	ALLOWABLE RANGE	#	STANDARD	MEASURED	ALLOWABLE RANGE
1	0	0	0~50	4	3015.3	* 2902.7	2924.9~3105.8
2	499	458	449~549	5	5056	* 4859.6	4904.3~5207.7
3	1002	963	952~1052				

GAS CO AS FOUND				SYSTEM G-101			Unit: ppm
#	STANDARD	MEASURED	ALLOWABLE RANGE	#	STANDARD	MEASURED	ALLOWABLE RANGE
1	35.1	* 29.5	32.1~38.1	2	100.5	* 84.8	97.5~103.5

TEMPERATURE AS FOUND				SYSTEM T-101			Unit: °F (°C)
#	STANDARD	MEASURED	ALLOWABLE RANGE	#	STANDARD	MEASURED	ALLOWABLE RANGE
1	32.1 (0.0)	32.8 (0.4)	31.1~33.1 (-0.5~0.6)	2	140.02 (60.01)	* 141.31 (60.73)	139.02~141.02 (59.45~60.57)

HUMIDITY AS FOUND				SYSTEM H-102			Unit: %RH
#	STANDARD	MEASURED	ALLOWABLE RANGE	#	STANDARD	MEASURED	ALLOWABLE RANGE
1	10.0	10.4	7.0~13.0	4	70.0	67.1	67.0~73.0
2	30.0	29.3	27.0~33.0	5	90.01	* 85.88	87.01~93.01
3	50.0	48.5	47.0~53.0				

*Indicates Out-of-Tolerance Condition

TSI does hereby certify that the above described instrument conforms to the original manufacturer's specification (not applicable to As Found data) and has been calibrated using standards whose accuracies are traceable to the United States National Institute of Standards and Technology (NIST) or has been verified with respect to instrumentation whose accuracy is traceable to NIST, or is derived from accepted values of physical constants. TSI's calibration system is registered to ISO-9001:2015.

Measurement Variable	System ID	Last Cal.	Cal. Due	Measurement Variable	System ID	Last Cal.	Cal. Due
5000 CO ₂	14A044095	04-06-20	04-06-25	200 CO	149886	04-30-20	03-24-28
N ₂	T-0608	05-19-20	05-19-28	Air	T17939	04-09-20	04-09-28
Flow	E003341	09-03-19	09-30-20	Flow	E003980	04-22-20	04-30-21
Flow	E003525	01-06-20	01-31-21	Flow	E003342	09-03-19	09-30-20
2000 C4H8	EB0054467	08-13-19	08-12-22	100 C4H8	CC507339	03-24-20	03-24-28
Temperature	E010657	02-14-20	02-28-21	Temperature	E010658	02-14-20	02-28-21
Temperature	E010655	01-21-20	01-31-21	Humidity	E003539	02-26-20	08-31-20

Chimera Use
VERIFIED

June 15, 2020

DATE

Doc ID CERT_GEN_WCC



CERTIFICATE OF CALIBRATION AND TESTING

TSI Incorporated, 500 Cardigan Road, Shoreview, MN 55126 USA
 Tel: 1-800-874-2811 1-651-490-2811 Fax: 1-651-490-3824 <http://www.tsi.com>

ENVIRONMENT CONDITIONS			MODEL	982
TEMPERATURE	70.41 (21.3)	°F (°C)	SERIAL NUMBER	P17100007
RELATIVE HUMIDITY	50.3	%RH		
BAROMETRIC PRESSURE	29.15 (987.1)	inHg (hPa)		

<input checked="" type="checkbox"/> AS LEFT	<input checked="" type="checkbox"/> IN TOLERANCE
<input type="checkbox"/> AS FOUND	<input type="checkbox"/> OUT OF TOLERANCE

- CALIBRATION VERIFICATION RESULTS -

TEMPERATURE VERIFICATION				SYSTEM T-101				Unit: °F (°C)
#	STANDARD	MEASURED	ALLOWABLE RANGE	#	STANDARD	MEASURED	ALLOWABLE RANGE	
1	22.1 (9.0)	31.9 (-0.1)	31.1-33.1 (-0.5-0.6)	2	140.0 (60.0)	140.5 (60.3)	139.0-141.0 (59.5-60.6)	

HUMIDITY VERIFICATION				SYSTEM H-102				Unit: %RH
#	STANDARD	MEASURED	ALLOWABLE RANGE	#	STANDARD	MEASURED	ALLOWABLE RANGE	
1	10.0	9.0	7.8-12.2	4	70.0	69.5	67.8-72.2	
2	30.0	29.1	27.8-32.2	5	90.0	88.7	87.8-92.2	
3	50.0	49.6	47.8-52.2					

CO2 GAS VERIFICATION				SYSTEM G-101				Unit: ppm
#	STANDARD	MEASURED	ALLOWABLE RANGE	#	STANDARD	MEASURED	ALLOWABLE RANGE	
1	0	0	0-50	4	3016	3012	2926-3107	
2	502	502	452-552	5	5056	5032	4904-5208	
3	1005	1019	955-1055					

CO GAS VERIFICATION				SYSTEM G-101				Unit: ppm
#	STANDARD	MEASURED	ALLOWABLE RANGE	#	STANDARD	MEASURED	ALLOWABLE RANGE	
1	35	36	32-38	2	101	100	98-104	

TSI does hereby certify that the above described instrument conforms to the original manufacturer's specification (not applicable to As Found data) and has been calibrated using standards whose accuracies are traceable to the United States National Institute of Standards and Technology (NIST) or has been verified with respect to instrumentation whose accuracy is traceable to NIST, or is derived from accepted values of physical constants. TSI's calibration system is registered to ISO-9001:2015.

Measurement Variable	System ID	Last Cal.	Cal. Due	Measurement Variable	System ID	Last Cal.	Cal. Due
Temperature	E010657	02-14-20	02-28-21	Temperature	E010658	02-14-20	02-28-21
Temperature	E010655	01-21-20	01-31-21	Humidity	E003539	02-26-20	08-31-20
5000 CO2	14A044095	04-06-20	04-06-25	200 CO	149886	04-30-20	03-24-28
N2	T-0608	05-19-20	05-19-28	Air	117939	04-09-20	04-09-28
Flow	E003341	09-03-19	09-30-20	Flow	E003980	04-22-20	04-30-21
Flow	E003525	01-06-20	01-31-21	Flow	E003342	09-03-19	09-30-20
2000 C4H8	EB0054467	08-13-19	08-12-22	100 C4H8	CC507339	03-24-20	03-24-28

ChaoVang

CALIBRATED

June 16, 2020

DATE

D:\CHD-CERT_GEN_WCC