

Radon Test Report

November 13, 2023

Batch #: 110923-4

Customer:

ATI Inc.
9220 Rumsey Road
Ste.100
Columbia MD 21045

Test Site:

Carrollton ES
8300 Quintana St.
New Carrollton MD 20784
County

E-PERM® Electret Ion Chambers were used for radon screening measurements that were conducted at the above referenced test site by: ATI Inc.

The Results are as follows:

Serial	Type	Location	Test Start Date	Test End Date	Results (pCi/L)
SDM312	SST	Rm. 106	03-Nov-2023 2:13 PM	06-Nov-2023 7:15 AM	1.1
SDP226	SST	R101	03-Nov-2023 2:11 PM	06-Nov-2023 7:15 AM	0.7
SDR440	SST	Library	03-Nov-2023 2:15 PM	06-Nov-2023 7:18 AM	0.6
SDW936	SST	Counselor Office	03-Nov-2023 2:09 PM	06-Nov-2023 7:16 AM	3.7
SHG913	SST	Rm. 113	03-Nov-2023 2:18 PM	06-Nov-2023 7:18 AM	1.0
SHJ138	SST	Rm. A3	03-Nov-2023 2:24 PM	06-Nov-2023 7:22 AM	0.6
SKZ842	SST	Principle Office	03-Nov-2023 2:12 PM	06-Nov-2023 7:16 AM	1.2
SMA807	SST	Rm. A4	03-Nov-2023 2:23 PM	06-Nov-2023 7:29 AM	1.7
SMT777	SST	R118	03-Nov-2023 2:20 PM	06-Nov-2023 7:24 AM	0.5
SMT974	SST	R201	03-Nov-2023 2:16 PM	06-Nov-2023 7:23 AM	1.2

Deployed By:

Retrieved By:

Analyzed By: Kimberly Cage 20SS034

Reader S/N: E0125 **Reader Calibration Due:** 8/2/2024

Conditions: Closed-Building Conditions Not Met

Mitigation: Unknown

Radon Health Risk Information

Radon is the second leading cause of lung cancer after smoking. The U.S. Environmental Protection Agency (EPA) and the Surgeon General strongly recommend that further action be taken when a home's radon test results are 4.0 pCi/L or greater. The national average indoor radon level is about 1.3 pCi/L. The higher the home's radon level, the greater the health risk to you and your family. Reducing your radon levels can be done easily, effectively and fairly inexpensively. Even homes with very high radon levels can be reduced below 4.0 pCi/L. Please refer to the EPA website at www.epa.gov/radon for further information to assist you in evaluating your test results or deciding if further action is needed.

Signature: Kimberly Cage Date: 14-Nov-2023