

Radon test result report for:**CENTRAL HS
MAIN**

Kit #	Room Id	Started	Ended	pCi/L	Analyzed
11292402	103	2023-11-03 @ 12:00 pm	2023-11-06 @ 3:00 pm	2.2 ± 0.3	2023-11-09
11292407	107	2023-11-03 @ 12:00 pm	2023-11-06 @ 3:00 pm	1.9 ± 0.3	2023-11-09
11292408	108	2023-11-03 @ 12:00 pm	2023-11-06 @ 3:00 pm	1.8 ± 0.3	2023-11-09
11292416	113	2023-11-03 @ 12:00 pm	2023-11-06 @ 3:00 pm	0.7 ± 0.3	2023-11-09
11292413	202	2023-11-03 @ 12:00 pm	2023-11-06 @ 3:00 pm	2.0 ± 0.3	2023-11-09
11292414	204	2023-11-03 @ 12:00 pm	2023-11-06 @ 3:00 pm	2.5 ± 0.3	2023-11-09
11292415	206	2023-11-03 @ 12:00 pm	2023-11-06 @ 3:00 pm	1.4 ± 0.3	2023-11-09
11292403	208	2023-11-03 @ 12:00 pm	2023-11-06 @ 3:00 pm	1.5 ± 0.3	2023-11-09
11292406	211	2023-11-03 @ 12:00 pm	2023-11-06 @ 4:00 pm	1.0 ± 0.3	2023-11-09
11292410	214	2023-11-03 @ 12:00 pm	2023-11-06 @ 4:00 pm	1.2 ± 0.3	2023-11-09
11292412	219	2023-11-03 @ 12:00 pm	2023-11-06 @ 4:00 pm	2.4 ± 0.3	2023-11-09
11292411	222	2023-11-03 @ 12:00 pm	2023-11-07 @ 11:00 am	1.5 ± 0.3	2023-11-09
11292422	223	2023-11-03 @ 12:00 pm	2023-11-07 @ 11:00 am	1.9 ± 0.3	2023-11-09
11292404	224	2023-11-03 @ 12:00 pm	2023-11-06 @ 4:00 pm	2.7 ± 0.3	2023-11-09
11292417	HEALTH SUITE	2023-11-03 @ 12:00 pm	2023-11-06 @ 3:00 pm	1.8 ± 0.3	2023-11-09
11292420	KITCHEN OFFICE	2023-11-03 @ 12:00 pm	2023-11-06 @ 3:00 pm	0.9 ± 0.3	2023-11-09
11292423	KITCHEN OFFICE	2023-11-03 @ 12:00 pm	2023-11-06 @ 3:00 pm	0.7 ± 0.3	2023-11-09
11292418	PRINCIPALS OFFICE	2023-11-03 @ 12:00 pm	2023-11-06 @ 3:00 pm	< 0.3	2023-11-09
11292419	PRINCIPALS OFFICE	2023-11-03 @ 12:00 pm	2023-11-06 @ 3:00 pm	1.4 ± 0.3	2023-11-09
11292401	TEACHER LOUNGE	2023-11-03 @ 12:00 pm	2023-11-06 @ 3:00 pm	0.6 ± 0.3	2023-11-09
11292405	TEACHER LOUNGE	2023-11-03 @ 12:00 pm	2023-11-06 @ 3:00 pm	1.6 ± 0.3	2023-11-09