

## Findings

### Radon Sampling

The laboratory results of the radon testing canisters collected at Charles Herbert Flowers High School had concentrations below the EPA action level of 4 pCi/L. Radon sampling results are summarized in Table 1. The complete laboratory analysis reports can be found in Attachment A.

**Table 1**  
**Radon Sampling Results**  
**Samples Measured from November 3, 2023, to November 6, 2023**

<b>Device Number</b>	<b>Room Number / Location</b>	<b>Result (pCi/L)</b>
7280036	406	0.8
7280037	408	0.7
7280038	410	0.4
7280039	418	0.6
7280040	717	0.4
7280041	727	0.4
7280042	1019	<0.4
7280043	123	0.6
7280044	122	0.4
7280045	104	<0.4
7280116	127	0.6
7280117	1004	<0.4
7280118	743	<0.4
7280119	1204	0.5
7280120	1208	0.5
7280121	745	<0.4
7280122	1426	0.5
7280123	1420	0.9
7280124	762	0.6
7280125	750	0.6
7280076	775	0.7
7280077	775	0.8
7280078	Auditorium- Stage	0.7
7280079	Auditorium- Audience	0.7
7280080	702	0.5
7280081	702 Duplicate	<0.4
7280082	717 Duplicate	0.5
7280033	Field Blank	<0.4

Note: pCi/L - picocuries per liter of air