

Findings

Radon Sampling

The laboratory results of the radon testing canisters collected at Ernest Everett Just Middle School had concentrations below the EPA action level of 4 pCi/L. Radon sampling results are summarized in Table 1. The complete laboratory analysis reports can be found in Attachment A.

Table 1
Radon Sampling Results
Samples Measured from November 3, 2023 to November 6, 2023

Device Number	Room Number / Location	Result (pCi/L)
7280075	141	0.8
7280074	141 Duplicate	0.7
7280073	135	0.4
7280072	213	0.5
7280071	214A	0.4
7280070	171	<0.4
7280069	170	<0.4
7280068	174	0.5
7280067	176	<0.4
7280066	175	<0.4
7280106	172	<0.4
7280111	166	0.4
7280110	166 Duplicate	<0.4
7280113	164	<0.4
7280109	148	0.5
7280112	144	0.7
7280107	129	0.4
7280108	156	0.4
7280090	158	0.5
7280089	134	<0.4
7280029	BLANK	<0.4

Note: pCi/L - picocuries per liter of air