



The radon analysis indicates that the radon gas concentrations detected in all areas assessed on the first floor of Frances Fuchs Early Childhood Center were below the Action Limit of 4pCi/L recommended by the EPA. The field blank sample was also below the acceptable limit and was within the typical +/- uncertainty for this analytical method. A summary of the analytical results is provided in Table 1 below. The laboratory analysis report is included as Attachment A.

**Table 1: Radon in Air Sample Results
Frances Fuchs Early Childhood Center
November 17 – November 20, 2023**

Test Kit ID	Location	Result (pCi/L)	EPA Action Level (pCi/L)
4978664	First Floor Main Office	0.5	4.0
4988228	First Floor Faculty Lounge 1	1.0	
4988227	First Floor Room 20	0.8	
4988279	First Floor Room 21	1.8	
4988288	First Floor Office 5	0.4	
4988259	First Floor Room 5	< 0.4	
4988249	First Floor Room 10	0.9	
4988298	First Floor Room 15	0.7	
4988238	First Floor Media Center	1.4	
4988269	First Floor Room 19A	0.9	
4988258	First Floor Room 4	0.9	
4988268	First Floor Room 17A	1.0	
4988299	First Floor Conference Room Field Blank	< 0.4	
4988289	First Floor Room 24	0.9	
4988229	First Floor Room 14	0.8	
4988247	First Floor Conference Room	0.8	
4988237	First Floor Nurse's Office	0.8	
4988248	First Floor Cafeteria	0.6	
4988278	First Floor Room 1	2.7	