



EMSL Analytical, Inc.

200 Route 130 North, Cinnaminson, NJ 08077
Phone/Fax: (800) 220-3675 / (856) 786-0327
<http://www.EMSL.com> cinnaminsonradonlab@emsl.com

EMSL Order: 382306640
CustomerID: GLBW42
CustomerPO:
ProjectID:

Attn: **Channa Bambaradeniya**
Global Inc.
1818 New York Avenue NE
Suite 222
Washington, DC 20002

Phone: (202) 832-1433
Fax:
Received: 11/1/2023 01:10 PM
Analysis Date: 11/2/2023
Collected: 10/27/2023

Project: **Port Towns ES / 4351 58th Avenue**

Test Site: **Port Towns ES**
4351 58th Avenue
Bladensburg, MD 20710

Test Report: Radon in Air Test Results

Samples for EMSL Kit 308151

Liquid Scintillation ID	Location	Radon Activity pCi/L	Start	Stop	Temperature F	Humidity %	Sample Type
549745	1034	0.6	10/27/2023	10/30/2023	70	53	Customer
382306640-0001			1:30:00 PM	7:22:00 AM			

Sample Notes:

Samples for EMSL Kit 308144

Liquid Scintillation ID	Location	Radon Activity pCi/L	Start	Stop	Temperature F	Humidity %	Sample Type
549739	1035	0.6	10/27/2023	10/30/2023	70	53	Customer
382306640-0002			1:35:00 PM	7:18:00 AM			

Sample Notes:

Samples for EMSL Kit 308137

Liquid Scintillation ID	Location	Radon Activity pCi/L	Start	Stop	Temperature F	Humidity %	Sample Type
549806	1046	0.4	10/27/2023	10/30/2023	70	53	Customer
382306640-0003			1:38:00 PM	7:20:00 AM			

Sample Notes:

Samples for EMSL Kit 308146

Liquid Scintillation ID	Location	Radon Activity pCi/L	Start	Stop	Temperature F	Humidity %	Sample Type
549785	1053	0.6	10/27/2023	10/30/2023	70	53	Customer
382306640-0004			1:45:00 PM	7:17:00 AM			

Sample Notes:

Samples for EMSL Kit 308148

Liquid Scintillation ID	Location	Radon Activity pCi/L	Start	Stop	Temperature F	Humidity %	Sample Type
549734	1122	0.3	10/27/2023	10/30/2023	70	53	Customer
382306640-0005			1:53:00 PM	7:00:00 AM			

Sample Notes:

547732	1122	0.5	10/27/2023	10/30/2023	70	53	Duplicate
382306640-0006			1:53:00 PM	7:00:00 AM			

Sample Notes:

Duplicate RPD = 50%



EMSL Analytical, Inc.

200 Route 130 North, Cinnaminson, NJ 08077
Phone/Fax: (800) 220-3675 / (856) 786-0327
<http://www.EMSL.com> cinnaminsonradonlab@emsl.com

EMSL Order: 382306640
CustomerID: GLBW42
CustomerPO:
ProjectID:

Attn: **Channa Bambaradeniya**
Global Inc.
1818 New York Avenue NE
Suite 222
Washington, DC 20002

Phone: (202) 832-1433
Fax:
Received: 11/1/2023 01:10 PM
Analysis Date: 11/2/2023
Collected: 10/27/2023

Project: **Port Towns ES / 4351 58th Avenue**

Test Site: **Port Towns ES**
4351 58th Avenue
Bladensburg, MD 20710

Test Report: Radon in Air Test Results

Samples for EMSL Kit 308150

Liquid Scintillation ID	Location	Radon Activity pCi/L	Start	Stop	Temperature F	Humidity %	Sample Type
549760	1033	0.5	10/27/2023	10/30/2023	70	53	Customer
382306640-0007			2:00:00 PM	7:23:00 AM			

Sample Notes:

Samples for EMSL Kit 308136

Liquid Scintillation ID	Location	Radon Activity pCi/L	Start	Stop	Temperature F	Humidity %	Sample Type
549855	Multi Purpose Room	0.6	10/27/2023	10/30/2023	70	53	Customer
382306640-0008			2:05:00 PM	7:07:00 AM			

Sample Notes:

Samples for EMSL Kit 308153

Liquid Scintillation ID	Location	Radon Activity pCi/L	Start	Stop	Temperature F	Humidity %	Sample Type
549738	1124 Serving	0.5	10/27/2023	10/30/2023	70	53	Customer
382306640-0009			2:10:00 PM	7:05:00 AM			

Sample Notes:

Samples for EMSL Kit 308143

Liquid Scintillation ID	Location	Radon Activity pCi/L	Start	Stop	Temperature F	Humidity %	Sample Type
549728	1150	0.7	10/27/2023	10/30/2023	70	53	Customer
382306640-0010			2:15:00 PM	7:08:00 AM			

Sample Notes:

Samples for EMSL Kit 308141

Liquid Scintillation ID	Location	Radon Activity pCi/L	Start	Stop	Temperature F	Humidity %	Sample Type
549833	1144	0.8	10/27/2023	10/30/2023	70	53	Customer
382306640-0011			2:20:00 PM	9:00:00 AM			

Sample Notes:



EMSL Analytical, Inc.

200 Route 130 North, Cinnaminson, NJ 08077
 Phone/Fax: (800) 220-3675 / (856) 786-0327
<http://www.EMSL.com> cinnaminsonradonlab@emsl.com

EMSL Order: 382306640
 CustomerID: GLBW42
 CustomerPO:
 ProjectID:

Attn: **Channa Bambaradeniya**
Global Inc.
1818 New York Avenue NE
Suite 222
Washington, DC 20002

Phone: (202) 832-1433
 Fax:
 Received: 11/1/2023 01:10 PM
 Analysis Date: 11/2/2023
 Collected: 10/27/2023

Project: **Port Towns ES / 4351 58th Avenue**

Test Site: **Port Towns ES**
4351 58th Avenue
Bladensburg, MD 20710

Test Report: Radon in Air Test Results

Samples for EMSL Kit 308140

Liquid Scintillation ID	Location	Radon Activity pCi/L	Start	Stop	Temperature F	Humidity %	Sample Type
549820	1018	0.5	10/27/2023	10/30/2023	70	53	Customer
382306640-0012			2:23:00 PM	7:11:00 AM			

Sample Notes:

Samples for EMSL Kit 308155

Liquid Scintillation ID	Location	Radon Activity pCi/L	Start	Stop	Temperature F	Humidity %	Sample Type
549784	1014	0.7	10/27/2023	10/30/2023	70	53	Customer
382306640-0013			2:25:00 PM	7:13:00 AM			

Sample Notes:

549038	1014	0.1	10/27/2023	10/30/2023	70	53	Blank
382306640-0014			2:25:00 PM	7:13:00 AM			

Sample Notes:

Samples for EMSL Kit 308134

Liquid Scintillation ID	Location	Radon Activity pCi/L	Start	Stop	Temperature F	Humidity %	Sample Type
549755	1013	0.4	10/27/2023	10/30/2023	70	53	Customer
382306640-0015			2:26:00 PM	7:14:00 AM			

Sample Notes:

Samples for EMSL Kit 308147

Liquid Scintillation ID	Location	Radon Activity pCi/L	Start	Stop	Temperature F	Humidity %	Sample Type
549777	1008	0.7	10/27/2023	10/30/2023	70	53	Customer
382306640-0016			2:28:00 PM	7:12:00 AM			

Sample Notes:

Samples for EMSL Kit 308133

Liquid Scintillation ID	Location	Radon Activity pCi/L	Start	Stop	Temperature F	Humidity %	Sample Type
549759	1000	0.7	10/27/2023	10/30/2023	70	53	Customer
382306640-0017			2:30:00 PM	7:09:00 AM			

Sample Notes:



EMSL Analytical, Inc.

200 Route 130 North, Cinnaminson, NJ 08077
Phone/Fax: (800) 220-3675 / (856) 786-0327
<http://www.EMSL.com> cinnaminsonradonlab@emsl.com

EMSL Order: 382306640
CustomerID: GLBW42
CustomerPO:
ProjectID:

Attn: **Channa Bambaradeniya**
Global Inc.
1818 New York Avenue NE
Suite 222
Washington, DC 20002

Phone: (202) 832-1433
Fax:
Received: 11/1/2023 01:10 PM
Analysis Date: 11/2/2023
Collected: 10/27/2023

Project: **Port Towns ES / 4351 58th Avenue**

Test Site: **Port Towns ES**
4351 58th Avenue
Bladensburg, MD 20710

Test Report: Radon in Air Test Results

Samples for EMSL Kit 308149

Liquid Scintillation ID	Location	Radon Activity pCi/L	Start	Stop	Temperature F	Humidity %	Sample Type
549867	1049	0.4	10/27/2023	10/30/2023	70	53	Customer
382306640-0018			2:32:00 PM	7:19:00 AM			

Sample Notes:

The radon test was performed using a liquid scintillation radon detector/s and counted on a liquid scintillation counter using approved EPA testing protocols for Radon in Air testing. The EPA recommends fixing your home if the average of two short-term tests taken in the lowest lived-in level of the home show radon levels that are equal to or greater than 4.0pCi/L. The EPA recommends retesting your home every two years.

Please contact EMSL Analytical, Inc. or your State Health Department for further information.
All procedures used for generating this report are in complete accordance with the current EPA protocols for the analysis of Radon in Air.

Report Note

Analyst(s)

Jeanel Zoll (18)

Dominic Gehret, Radiochemistry Laboratory Manager, NJ Radon
Measurement Specialist MES 13910
or other approved signatory

In no event shall EMSL be liable for indirect, special, consequential, or incidental damages, including, but not limited to, damages for loss of profit or goodwill regardless of the negligence (either sole or concurrent) of EMSL and whether EMSL has been informed of the possibility of such damages, arising out of or in connection with EMSL's services thereunder or the delivery, use, reliance upon or interpretation of test results by client or any third party. We accept no legal responsibility for the purposes for which the client uses the test results. In no event shall EMSL be liable to a client or any third party, whether based upon theories of tort, contract or any other legal or equitable theory, in excess of the amount paid to EMSL by client thereunder. The test results meets all NELAC requirements unless otherwise specified.

Samples analyzed by EMSL Analytical, Inc. Cinnaminson, NJ FL RB2034/R2687,IL RNL2008202,IN RTL00935,IA RNLAB10005,KS KS-LB-0005/KS-MS-0482,ME SPC202,MN RL-0005,NE 474/RMB-1083,NJ 03036/MEB92525/MES13910,NY 10872,OH RL39,OK D9952,PA 2573/3393/68-00367,RI RMB-108/RI00179,WV RL000220,NRSB-ARL6006,NRPP

Initial report from 11/06/2023 11:38:23

Please visit www.radontestinglab.com