

Radon Test Report

November 28, 2023

Batch #: 112823-3

Customer:

ATI Inc.
9220 Rumsey Road
Ste.100
Columbia MD 21045

Test Site:

Thurgood Marshall MS
4909 Brinkley Rd.
Camp Springs MD

E-PERM® Electret Ion Chambers were used for radon screening measurements that were conducted at the above referenced test site by: ATI Inc.

The Results are as follows:

Serial	Chamber	Type	Location	Test Start Date	Test End Date	Results (pCi/L)
SKZ798		SST	Room 129	17-Nov-2023 6:38 AM	20-Nov-2023	
SKZ809		SST	Room212	17-Nov-2023 6:29 AM	20-Nov-2023 6:26 AM	1.0
SKZ844		SST	Room 126	17-Nov-2023 6:42 AM	20-Nov-2023 6:37 AM	0.7
SLD303		SST	Room 124	17-Nov-2023 6:44 AM	20-Nov-2023 6:38 AM	1.5
SLH590		SST	Room 203	17-Nov-2023 6:18 AM	20-Nov-2023 6:19 AM	1.4
SLY618		SST	Room 106	17-Nov-2023 6:58 AM	20-Nov-2023 6:55 AM	2.0
SLY977		SST	Room 208	17-Nov-2023 6:24 AM	20-Nov-2023 6:25 AM	0.8
SMA092		SST	Room 117	17-Nov-2023 6:50 AM	20-Nov-2023 6:47 AM	0.8
SMA731		SST	Room 219	17-Nov-2023 6:22 AM	20-Nov-2023 6:23 AM	1.6
SMA740		SST	Room 108	17-Nov-2023 6:54 AM	20-Nov-2023 6:50 AM	0.8
SMA870		SST	Library	17-Nov-2023 6:35 AM	20-Nov-2023 6:15 AM	1.2
SMT716		SST	Room 127	17-Nov-2023 6:40 AM	20-Nov-2023 6:36 AM	1.8
SMT982		SST	Room 123	17-Nov-2023 6:46 AM	20-Nov-2023 6:38 AM	1.2
SMZ187		SST	Room 217	17-Nov-2023 6:20 AM	20-Nov-2023 6:22 AM	0.8
SMZ426		SST	Room 101	17-Nov-2023 7:02 AM	20-Nov-2023 6:58 AM	1.1
SNA149		SST	Room 210	17-Nov-2023 6:28 AM	20-Nov-2023 6:29 AM	1.8
SNB296		SST	Room 109	17-Nov-2023 6:56 AM	20-Nov-2023 6:33 AM	1.1
SNB406		SST	Room 114	17-Nov-2023 6:52 AM	20-Nov-2023 6:48 AM	1.2
SNB557		SST	Room 121	17-Nov-2023 6:48 AM	20-Nov-2023 6:40 AM	2.0

Deployed By: Mikal Frater

Retrieved By:

Analyzed By: Kimberly Cage 20SS034

Reader S/N: E0125

Reader Calibration Due: 8/2/2024

Conditions: Closed-Building Conditions Not Met

Comment: SDP313 is Missing

Radon Health Risk Information

Radon is the second leading cause of lung cancer after smoking. The U.S. Environmental Protection Agency (EPA) and the Surgeon General strongly recommend that further action be taken when a home's radon test results are 4.0 pCi/L or greater. The national average indoor radon level is about 1.3 pCi/L. The higher the home's radon level, the greater the health risk to you and your family. Reducing your radon levels can be done easily, effectively and fairly inexpensively. Even homes with very high radon levels can be reduced below 4.0 pCi/L. Please refer to the EPA website at www.epa.gov/radon for further information to assist you in evaluating your test results or deciding if further action is needed.

Signature: Kimberly Cage

Date: 28-Nov-2023