

# Radon Test Report

November 22, 2023

Batch #: 111723-1

**Customer:**

ATI Inc.  
9220 Rumsey Road  
Ste.100  
Columbia MD 21045

**Test Site:**

University Park ES  
4315 Underwood Street  
University Park MD 20782

---

E-PERM® Electret Ion Chambers were used for radon screening measurements that were conducted at the above referenced test site by: ATI Inc.

**The Results are as follows:**

Serial	Chamber	Type	Location	Test Start Date	Test End Date	Results (pCi/L)
SDG647		SST	Room 405	10-Nov-2023 2:23 PM	13-Nov-2023 7:12 AM	1.2
SDG744		SST	Room 302	10-Nov-2023 2:31 PM	13-Nov-2023 7:14 AM	0.4
SJX121		SST	Kitchen	10-Nov-2023 2:19 PM	13-Nov-2023 7:10 AM	1.3
SKU879		SST	Storage	10-Nov-2023 2:18 PM	13-Nov-2023 7:10 AM	1.0
SLH479		SST	Room 402	10-Nov-2023 2:26 PM	13-Nov-2023 7:12 AM	0.6
SLY265		SST	Room 301	10-Nov-2023 2:29 PM	13-Nov-2023 7:13 AM	0.6
SLY775		SST	Room 401	10-Nov-2023 2:23 PM	13-Nov-2023 7:12 AM	0.8
SLY972		SST	Boiler Room	10-Nov-2023 2:19 PM	13-Nov-2023 7:11 AM	0.6
SMC624		SST	Room 403	10-Nov-2023 2:25 PM	13-Nov-2023 7:12 AM	1.1
SMY441		SST	Room 305	10-Nov-2023 2:29 PM	13-Nov-2023 7:13 AM	0.7

**Deployed By:**

**Retrieved By:**

**Analyzed By:** Kimberly Cage 20SS034

**Reader S/N:** E0125 **Reader Calibration Due:** 8/2/2024

**Conditions:** Closed-Building Conditions Not Met

**Mitigation:** Unknown

---

## Radon Health Risk Information

Radon is the second leading cause of lung cancer after smoking. The U.S. Environmental Protection Agency (EPA) and the Surgeon General strongly recommend that further action be taken when a home's radon test results are 4.0 pCi/L or greater. The national average indoor radon level is about 1.3 pCi/L. The higher the home's radon level, the greater the health risk to you and your family. Reducing your radon levels can be done easily, effectively and fairly inexpensively. Even homes with very high radon levels can be reduced below 4.0 pCi/L. Please refer to the EPA website at [www.epa.gov/radon](http://www.epa.gov/radon) for further information to assist you in evaluating your test results or deciding if further action is needed.

---

Signature: Kimberly Cage Date: 22-Nov-2023